

C/87

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/WZ/2025/ 81

Dated: 09/07/2025

To

Dr. Ram Kailash Gupta,
B-71/2, Wazirpur Industrial Area,
New Delhi- 110052.

Sub:- Regarding issuance of Fire Safety Certificate in r/o Dr. Ram Kailash Gupta coaching institute located at B-71/2, Wazirpur Industrial Area, New Delhi- 110052.

Sir,

Please refer to your e-mail received through Id directorcdl@teania.in dated 05.05.2025 on the subject cited above. The building was re-inspected by officers concerned of Delhi Fire Service to check the required fire safety measures of the above building as per NBC Part-IV for the educational occupancy.

During inspection, it was observed that the building is comprised of basement, stilt and three upper floors served by two staircases. Fire fighting arrangements such as fire extinguishers, hose reel hose, automatic sprinkler system in basement floor, down comer system, terrace pump capacity 900 LPM, exit signages etc. found provided. However, the following shortcomings were observed: -

1. Overhead water storage tank capacity 10,000 liters provided against the requirement of 15000 lts.
2. Fire check door is not provided at the suitable location in basement floor.
3. Removal of class room in wooden board participation at basement floor is under progress.
4. The classroom in upper floors made with wooden board shall be removed.
5. Terrace pump not found in auto mode.

In view of above, issuance of fire safety certificate cannot be consider at this stage & rejected. You are advised to remove the above mentioned shortcomings under intimation to this department.

Yours faithfully

(Atul Garg)
Director

Copy to: -

1. The Executive Engineer (Bldg.), MCD, Keshavpuram Zone, Keshavpuram, New Delhi- 110034.

07/07/2025