

e-26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No.F.6/DFS/MS/School/2026/SZ/06

Dated: 09/01/2026

FIRE SAFETY CERTIFICATE

Certified that the building of **Rao Bir Singh Public School, Located at Gali No. 2, Near Oberoi Farm, Village Kapashera, New Delhi - 110037**, comprised of Ground + 2 Upper floor, was issued Fire Safety Certificate vide this department letter No. F.6/DFS/MS/School/2022/SZ/455 dated 25/04/2022. The premise was re-inspected by the officer concerned of this department on 06/12/2025 in the presence of Sh. Mahesh and found that said premises have deemed complied with the fire prevention and fire safety requirements in accordance Director of Education Circular No. 3298 to 3398 dated 01/03/2011, DOE Circular 01/03/2011 and that the said premises/building is fit for occupancy class "**Educational Group B**" with effect from 09/01/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/01/2026 at New Delhi by.


9/1/26
(A. K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Manager, RAO Bir Singh Public School, Gali no-2 Village Kapashera, Delhi - 110037
2. The Director of Education, MCD, Dr. SPM Civic Centre, JLN Marg, New Delhi-110002.

Condition for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The trained firefighting staff should be available at the site round the clock.
6. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning authority.
7. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any. Basement shall be used as per BBL concerned.
9. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

2/14

INSPECTION REPORT

1.	Name & address of the building	Rao Bir Singh Public School, Located at Gali No. 2, Near Oberoi Farm, Village Kapashera, New Delhi - 110037		
2.	Type of occupancy	Educational, Group B (School)		
3.	Building Comprised of	Ground + 2 Upper floor		
4.	Type of case	Renewal		
5.	Details of previous FSC No.	F.6/MS/DFS/School/2022/SZ/455 Dt. 25.04.2022		
6.	Fire safety directives No.-	DOE Circular 01/03/2011		
7.	Date of inspection: -	28/11/2025		
8.	Name of the inspecting officer: -	Kaushal Kishore, ADO (SJ)		
9.	Name & designation of officer from the building side: -	Sh. Mahesh (Director)		
10.	Year of construction: -	2006-2011		
11.	Applicant's letter No: -	Letter No. Nil dated 02/09/2025 vide office diary No. 5547 dated 22/09/2025		
S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	• Road width	6 Mtr	6 Mtr	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	02 Nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircase			
	• Upper floors	1.5m / 0.75m	1.30m & 1.25m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01	Provided	MR
	e. Width of corridor	1.50m	Provided	MR
	f. Door size	01 m	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain (Basement)	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation	M/R
5.	Fire Extinguishers			
	• Total numbers	06 Nos.	10 Nos.	MR
	• Types	ABC/CO2	ABC & CO2	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	02 Nos.	02 Nos.	MR
	• Length of hose reel hose	30m	30m	MR

7.	Automatic Fire Detection & Alarming System.			
	• Type of detectors (Smoke)	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	Ground level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Stand by pump output	N/A	N/A	N/A
	• Stand by pump head	N/A	N/A	N/A
	• Auto starting/Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	Terrace level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of pump	40m	40m	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 ltrs	10,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication	N/A	N/A	N/A

2/16

	• Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	N/A	N/A	N/A

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/School/2022/SZ/455 dated 25/04/2022, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, **DFA is put up for approval & signature please.**


30/1/25

Signature of the Inspecting Officer
Name: Kaushal Kishore
Designation: ADO (SJ)



DO (SD)


31/1/25


31/1/25



11/1/26

A.K. MALIK
Principal Director

My. CFO to 

02/01/26

My. CFO (SZ)



A.K. MALIK
DO (SD) 
31/1/25

11/01/25

2/17

RT letter is prepared and put-up for signature pl.

~~DUF/SZ~~

~~A. K. Malik~~
9/1/26

A. K. MALIK

M.S. cell

~~(A. K. Malik)~~
8/1/26
(Kausmalikar)
ADD/ST