



No. F6/DFS/MS/School/NDZ/2025/ 719

Dated: 30/05/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Rashtriya Public School located at C – 39, west Vinod Nagar, Opp., Saraswati Kunj, I.P Extn., Delhi – 110092**, comprised of ground plus three upper floors, **but school running on ground plus one upper floor only** owned/occupied by **Rashtriya Public School** was granted Fire Safety Certificate by this department vide letter No. F6/MS/DFS/2006/3484 dated 01/12/2006. The School building was re-inspected by the officer concerned of this department on 10/05/2025 in presence of Mrs. Shashi Bala (Principal) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262 - 362 dated 17/01/2005 issued by Director of Education and the building premises is fit for occupancy of class Group B **“Educational Building”** with effect from 30/05/2025 for **ground plus one upper floor only** a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 30/05/2025 at New Delhi by.

  
(ATUL GARG)  
DIRECTOR  
o/c DELHI FIRE SERVICE

**Copy to: -**

1. The Director of Education (GNCT), Old Secretariat, Delhi - 110054.
2. The Principal, Rashtriya Public School located at C – 39, west Vinod Nagar, Opp., Saraswati Kunj, I.P Extn., Delhi – 110092.

**Conditions for the validity of Fire Safety Certificate**

1. **This fire safety certificate is valid for ground plus one upper floor only.**
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
7. At the time of inspection second floor, third floor vacant and not in use.
8. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**INSPECTION REPORT**

1	Name & address of the building	Rashtriya Public School located at C - 39, west Vinod Nagar, Opp., Saraswti Kunj, I.P Extn., Delhi - 110092.				
2	Building is comprised of	Ground plus three upper floors. <b>But School running on ground plus one upper floor only.</b>				
3	Type of occupancy	Educational Building				
4	Type of case	Renewal Case				
5	Details of previous FSC	F6/MS/DFS/2006/3484 dated 01/12/2006				
6	Fire safety directives letter no.	Circular No. 262 - 362 dated 17/01/2005				
7	Date of inspection	10/05/2025				
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/ Laxmi Nagar				
9	Name of the designation of officer from the building side	Mrs. Shashi Bala (Principal)				
10	Year of construction	2000				
11	Applicant's letter no.	Outdoor diary no. 14872 dated 24/03/2025				
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR		
<b>1</b>	<b>Access to Building:</b>					
	A	Road width	6.0 meters.	6.0 meters.	MR	
	B	Gate width	N/A	N/A	N/A	
	C	Width of internal road	N/A	N/A	N/A	
<b>2</b>	<b>Number, Width, Type and Arrangement of Exits:</b>					
	A	Number of staircases				
		a	Upper floor	01 no.	02 no.	MR
		b	Basement	N/A	N/A	N/A
	B	Width of staircases				
		a	Upper floor	1.50 meters	81 cm & 85 cm	MR (Old Accepted)
		b	Basement	N/A	N/A	N/A
	C	Protection of exits				
		a	Fire check door	N/A	N/A	N/A
		b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace	01 no.	01 no.	MR	
	E	Width of corridor	Required	Provided	MR	
	F	Door size	1.0 meter.	1.0 meter.	MR	
<b>3</b>	<b>Compartmentation:</b>					
	A	Fire check door	N/A	N/A	N/A	
	B	Sealing of electrical shafts	N/A	N/A	N/A	
	C	Fire rating of shaft door	N/A	N/A	N/A	
	D	Water curtain	N/A	N/A	N/A	
	E	Fire dampers	N/A	N/A	N/A	
<b>4</b>	<b>Smoke Management System:</b>					
	A	Basement	N/A	N/A	N/A	
	B	Upper floor	N/A	N/A	N/A	


<b>5. Fire Extinguisher:</b>					
	A	Total numbers	06 nos.	08 nos.	MR
	B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	C	ISI marking	ISI Marked	Provided	MR
<b>6 First-Aid-Hose Reel:</b>					
	A	Total numbers of each floor	01 no.	01 no.	MR
	B	Length of hose reel hose	30 mtr.	30 mtr.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
<b>7 Automatic Fire Detection and Alarming System:</b>					
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
<b>8 MOEFA:</b>			N/A	N/A	N/A
<b>9 Public Address System:</b>			N/A	N/A	N/A
<b>10 Automatic Sprinkler System:</b>					
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11 Internal Hydrants:</b>					
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
<b>12 Yard Hydrants:</b>					
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
<b>13 Pumping Arrangements:</b>					
<b>1 Ground level</b>					
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
<b>2 Terrace Level</b>					
	A	Discharge of pump	220 LPM	220 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>			
	<b>A</b>	Underground tank capacity	N/A	N/A
	<b>B</b>	Draw-off connection	N/A	N/A
	<b>C</b>	Fire service inlet	N/A	N/A
	<b>D</b>	Access to tank	N/A	N/A
	<b>E</b>	Overhead tank capacity	1500 liters	2000 liters
<b>15</b>	<b>Exit Signage:</b>		Required	Provided
<b>16</b>	<b>Provision of Lifts:</b>			
	<b>A</b>	Pressurization of lift shaft	N/A	N/A
	<b>B</b>	Pressurization of lift lobby	N/A	N/A
	<b>C</b>	Communication in lift car	N/A	N/A
	<b>D</b>	Firemen's grounding switch	N/A	N/A
	<b>E</b>	Lift signage	N/A	N/A
<b>17</b>	<b>Standby Power Supply:</b>			
<b>18</b>	<b>Refuge Area:</b>			
	<b>A</b>	Total area	N/A	N/A
	<b>B</b>	Location	N/A	N/A
<b>19</b>	<b>Fire Control Room:</b>			
	<b>A</b>	Detector system panel	N/A	N/A
	<b>B</b>	Flow switch panel	N/A	N/A
	<b>C</b>	PA system panel	N/A	N/A
	<b>D</b>	Battery backup	N/A	N/A
	<b>E</b>	Building floor plans	N/A	N/A
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>			

Note: - At the time of inspection that the school running ground + 01 floor and second & third floor vacant and not in use as per affidavit dated 04.04.2025 (Affidavit enclosed)

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection. The shortcoming issued by this department vide letter No. F6/DFS/MS/School/2018/NDZ/2202 dated 28/09/2018 has been rectified.   
 2012 1478 25/04/2012

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/MS/DFS/2006/3484 dated 01/12/2006 Renewal under rule 35 (6) of the Delhi Fire Rules 2010 is recommended.

  
 Signature of the Inspecting Officer  
 Name: - Yashwant Singh Meena  
 Designation: - ADO/Laxmi Nagar

D.O/EAST   
 19/05/2025   
 Dy CTO (MSZ)   
 C.F.O.   
 22/5/2025   
 Director   
 22/5/25   
 20/05/25   
 Anuj