



C20
19/12/2025

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2025/NDZ/ 1403

Dated: 19/12/2025

FIRE SAFETY CERTIFICATE

Certified that the R. D. Gurukulam School located at C-188/189, C- Block Gali No. 03, West Karawal Nagar, Delhi-110094, comprised of ground floor only owned/occupied by R. D. Gurukulam School. The premises was inspected by the officer concerned of this department on 21/11/2025 in the presence of Mr. Manish Tiwari, Manager and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" **Group B** with effect from 19/12/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 & also conditions printed below.

Issued on.....19/12/2025.....at New Delhi by.


17/12/25

(Dr. S. K. TOMAR)
DY. CHIEF FIRE OFFICER
o/c D. DELHI FIRE SERVICE

To,
The Manager, R. D. Gurukulam School located at C-188/189, C- Block Gali No. 03, West Karawal Nagar, Delhi-110094

Copy:-

The Director of Education, MCD
15th Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg, New Delhi-110002

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : R. D. Gurukulam School, C-188/189, C- Block,
Gali No. 03, West Karawal Nagar, Delhi-110094
2. Building is comprised of : Ground floor only
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : Delhi Fire Service Act 2007 & Rules, 2010
7. Date of Inspection : 21/11/2025
8. Name of the Inspecting officers : Deepak Kumar, ADO (Tahirpur)
9. Name and designation of Officer
from the building side : Mr. Manish Tiwari, Manager
10. Year of Construction : 2023
11. Applicant's letter No : rdgurululamschool2024@gmail.com
dated 15/11/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement NBC Part IV	Provided at Site	Remarks MR/NMR
01	Access to building			
	• Road width	06 mtrs	06 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	01 no.	N/A
	e. Width of Corridor	1.50 mtr.	1.50 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
		Required	Provided	MR
15	Exit Signage			
16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any.			

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rule. It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Deepak
24/11/2022

Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- A.D.O (Tahirpur)

DO (FO), B. attach school information form.

ADO (Tahirpur)

Deepak
24/11/2022

Sir, school information form is attached.

DO (FO)

Deepak
24/11/2022

Deepak
25/11/2022