



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/96

Dated: 10 /02/2025

To

The Incharge
R.D. Public School
Near Harizan Chaupal, Harizan Basti,
Kamalpur, Burari, Delhi-110084

Sub: - Regarding grant of fire safety certificate in r/o R.D. Public School located at Near Harizan Chaupal, Harizan Basti, Kamalpur, Burari, Delhi-110084.

Sir,

Please refer to your letter no- nil dated 09.01.2025 on the subject cited above. In this connection this is to inform you that the above mentioned school premises was inspected by the officer concerned of this department on 27.01.2025 in the presence of Smt. Permila (Incharge) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school premise is comprised of ground & first floor only. The observations/ shortcomings made are as under:-

1. All class room's door size is 90cm provided against the requirements of 01m each classroom.
2. Fire extinguisher is provided but not functional at the time of inspection.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully



(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.