

1102

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2026/244

Dated 26/03/2026

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Ridge Maidens Guest House, located at 1004-05, Naiwalan, Faiz Road, Karol Bagh, New Delhi – 110005 building comprised of Basement, Ground, Loft and 03 Upper Floors using Basement – Vacant/Storage, Ground Floor – Reception, Loft – Sealed, 1<sup>st</sup> Floor – 05 Guest Rooms, 2<sup>nd</sup> Floor – 06 Guest Rooms and 3<sup>rd</sup> Floor – 05 nos. Guest Rooms was issued FSC vide letter No. F6/DFS/MS/GH/NDZ/2023/63 dated 13/03/2023. Now, the Guest House premises was re-inspected by the officer concerned of this department on 12/03/26 in the presence of Sh. Anoop Nayyar, Owner and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy “Residential building: Group – A (Guest House) for Ground Floor (Reception), 1<sup>st</sup> Floor (05 Guest Rooms), 2<sup>nd</sup> Floor (06 Guest Rooms) and 3<sup>rd</sup> Floor (05 Guest Rooms) - Total 16 Guest Rooms only with effect from 26/03/2026 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued 26/03/2026 at New Delhi by.

  
23/3/26

(Dr. S. K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi.: Online ID – 2026022602082 dated 26/02/2026.
2. The Manager, M/s Ridge Maidens Guest House, 1004-05, Naiwalan, Faiz Road, Karol Bagh, New Delhi – 110005.

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

## INSPECTION REPORT

1.	Name & address of the building: -	M/s Ridge Maidens Guest House, 1004-05, Naiwalan, Faiz Road, Karol Bagh, New Delhi - 110005		
2.	Type of occupancy: -	Residential, "Group-A" (Guest House)		
3.	Building Comprised of: -	Basement + Ground + Loft + 03 Upper Floors Total 16 Guest Rooms Basement - Vacant/Storage Ground Floor - Reception Loft - Sealed 1 <sup>st</sup> Floor - 05 Guest Rooms 2 <sup>nd</sup> Floor - 06 Guest Rooms 3 <sup>rd</sup> Floor - 05 Guest Rooms		
4.	Type of case: -	Renewal		
5.	Details of previous FSC: -	F6/DFS/MS/GH/NDZ/2023/63 dated 13/03/2023		
6.	Fire safety directives No.: -	N/A		
7.	Date of inspection: -	12/03/2026		
8.	Name of the inspecting officer: -	Sh. Bhupender Prakash, ADO(CC)		
9.	Name & designation of officer From the building side: -	Sh. Anoop Nayyar, Owner		
10.	Year of construction: -	Before 2021		
11.	Applicant's letter No: -	MCD Online ID. 2026022602082 dated 26/02/2026		
S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	<b>Access to Building</b>			
	• Road width	Accessible	9.00 mtr.	MR*
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper floors	01 no.	01 no.	MR
	• Basements	02 nos.	02 nos.	MR
	<b>b. Width of staircase</b>			
	• Upper floors	1.25 mtr.	1.15 to 1.20 mtr.	MR
	• Basements	1.25 mtr.	1.60 & 0.95 mtr.	MR
	<b>c. Protection of exits</b>			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	01 no.	01 no.	MR
	<b>e. Width of corridor</b>	1.00 mtr.	1.15, 1.10 mtr.	MR
	<b>f. Door size</b>	1.00 mtr.	0.80 X 2.05 mtr.	MR
3.	<b>Compartmentation</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	Sealed	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	• Basements	Required	Provided Exhaust Fan	MR
	• Upper floors	Required	Provided Natural / Exhaust Fan	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	10 nos.	12 nos.	MR
	• Types	ABC & CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• ISI marking	Required	Provided	MR
6.	<b>First-Aid Hose Reel</b>			
	• Total number of each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR

	• Nozzle diameter	05 mm	05 mm	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System.</b>			
	• Type of detectors	CO	Provided	MR
	• Location of main panel	Ground Floor	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's Location	At each floor	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	Provided	MR/ Area less than 200 Sq.M.
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	Ground level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Stand by pump output	N/A	N/A	N/A
	• Stand by pump head	N/A	N/A	N/A
	• Auto starting/Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	Terrace level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of pump	30 mtr.	30 mtr.	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	5,000 ltr.	5,000 ltr.	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Fireman's switch			Old Lift
	• Lift signage	Required	Provided	MR
		Required	Provided	MR
<b>17.</b>	<b>Stand by Power Supply</b>	Required	Provided	
<b>18.</b>	<b>Refuge Area</b>			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

N/22

M/s Ridge Maidens Guest House, 1004-05, Naiwalan, Faiz Road, Karol Bagh, New Delhi - 110005

19.	<b>Fire Control Room</b>			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>	N/A	N/A	N/A

\*PNF - Provided but Non-Functional, \*MR - Meeting Requirement, \*NMR - Not Meeting Requirement

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter No. F6/DFS/MS/GH/NDZ/2023/63 dated 13/03/2023 under rule 35(6) of the Delhi Fire Service Rules 2010. The last date for deemed approval is 27/03/2026.

Accordingly, DFA is prepared and put up for perusal and signature please.

*Bhupender Prakash*  
17/3/2026  
Bhupender Prakash  
ADO (CC)

~~DO (CD)~~ *[Signature]*  
18/03/26

~~Dy. CFO (NDZ)~~ *[Signature]*  
18/3/26

~~Principal Director~~

~~Dy. CFO to Secy.~~  
*[Signature]*  
18/03/26

~~Dy. CFO (NDZ)~~

*[Signature]*  
23/3/26

Ad/CC

As approved F.O. letter is put up for signature pls.

~~Dy. CFO (NDZ)~~

*[Signature]*  
23/3/26

*Bhupender Prakash*  
23/3/2026

ms

Uploaded  
25/3/26 *[Signature]*