




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001



Dated 28/04/2025

No. F.6/DFS/MS/School/2025/NDZ/ 298

To,

The Manager,
Rosary Public School
B-5 South Anarkali,
Delhi-110051.

Sub:- Regarding Renewal of Fire Safety Certificate r/o Rosary Public School at B-5 South Anarkali
Delhi-110051.

Sir,

With reference to your letter no. RPS/320/25 dated 21/02/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on dated 19/04/2025 of the above mentioned School from fire safety point of view in presence of the Mr. Shashi Mohan Agnihotri. The building comprised of ground plus two upper floors only. Following shortcomings were observed during the time of inspection.

1. An additional staircase of width 0.75 meter shall be required.
2. First Aid Hose reels at 1st & 2nd floor found removed.
3. A terrace pump 240 lpm head 40 meters provided but not functional.
4. Exit signages are not provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned shortcomings under intimation to this office for further course of action.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education, MCD

Udyog Sadan, Plot No. 419, FIE, Patparganj Ind. Area, Delhi- 110092