





No. F.6/DFS/MS/School/2026/SZ/ 39

Dated: 25/03/2026

FIRE SAFETY CERTIFICATE

Certified that the **R.P. World School** located at Plot No. 207-237, Block-C, Deepak Vihar Extension, Vikas Nagar, Uttam Nagar, New Delhi-110059, comprised of ground floor only, owned/occupied by R.P. World School, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2014/SZ/1515 dated 03/12/2014. The said premise was re-inspected by the officer concerned of this department on 06/03/2026 in the presence of Mr. Aman Yadav (Manager) and found that the school building, now comprised of ground plus three upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the said building/premise is fit for occupancy class "Educational Group B-1" with effect from 25/03/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/03/2026 at New Delhi by


(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service


Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. The Manager, R.P. World School, Plot No. 207-237, Block-C, Deepak Vihar Extension, Vikas Nagar, Uttam Nagar, New Delhi-110059

Conditions for the validity of Fire Safety Certificate: -

1. This FSC is valid for the existing building only and not for another block under construction in the school premises. FSC for the additional construction shall be applied separate.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1.	Name & address of the building	R.P. World School, Plot No. 207-237, Block-C, Deepak Vihar Extension, Vikas Nagar, Uttam Nagar, New Delhi-110059		
2.	Type of Occupancy	Educational (Group B)		
3.	Building Comprised of	Ground + 03 Upper Floors.		
4.	Type of Case	Addition/Alteration.		
5.	Details of previous NOC No.	F6/DFS/MS/School/2014/SZ/1515 Dt. 03/12/2014 (For ground floor only)		
6.	Fire safety directives letter No.	NBC Part-IV/UBBL-2016		
7.	Date of inspection	06/03/2026		
8.	Name of the Inspecting Officer	ADO (JKP)		
9.	Name and designation of Officer from the building side	Mr. Aman Yadav (Manager)		
10.	Year of Construction	GF: 2014, UF: 2015 (FF, SF & TF)		
11.	Applicant's letter No.	Received through e-mail dated 01.03.2026 from mail Id. amansagar1231@gmail.com		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	NBC/UBBL Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6.0 mtr	Provided	MR
	• Gate width	4.5 mtr	6.5 mtr (02 Nos)	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos	02 Nos	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50m	1.50 mtr each	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	02 Nos	Provided	MR
	e. Width of Corridor	1.50 mtr	Provided	MR
	f. Door Size	1.0 mtr	1.0 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	03 Nos/Floor	22 Nos	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02 Nos	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

JKP

-0

N-3

7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 & 450 LPM	MR
	➤ Head of the pump	40 mtr	40 mtr each	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltrs	20,000 ltrs	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

SA

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A

Note: Additional constriction work is also in progress, adjacent to existing building within the school premises. However, this FSC is recommended for the existing building only as per attached photograph/drawing.

The fire protection systems provided in the building/premises were tested, checked at random and **found functional at the time of inspection.**

In view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, issuance of fire safety certificate **under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, DFA is put up for approval & signature please.

S Kumar
 10.03.26
 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (JKP)

~~DO (SW)~~

[Signature]
 16/3/26
 RAJINDER ATWAL
 D.F.O (S2)

[Signature]
 17/3/26
 A.K. MALIK

[Signature]
 Principal Director

my. CFO to Secy.

[Signature]
 19/02/26

~~my. CFO (S2)~~

[Signature]
 D.O (S2)

[Signature]
 19/3/26
 A.K. MALIK

[Signature]
 20/3
 ADO (JKP)
 JKP

P.T-D