



EM

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/2026/School/ 45

Dated: 02/04/2026

**FIRE SAFETY CERTIFICATE**

Certified that the R.S.M Public School at A-34, Gali No-1, Prem Nagar-III, Kirari Suleman Nagar, Delhi-110086 comprised of Ground & 02 upper floors only owned/ occupied by the R.S.M Public School have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 20/01/2026 in the presence of Sh. Rahul Saharan (Principal) and that the building/premises is fit for occupancy Class "Group B Educational (School)" with effect from .....02/04/2026 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...02/04/2026... at New Delhi

(S.K. Dua)

Dy. Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. The Deputy Director of Education, MCD, Sector-5, Rohini Zone, Delhi – 110085.
2. The Principal, R.S.M Public School at A-34, Gali No-1, Prem Nagar-III, Kirari Suleman Nagar, Delhi-110086.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

119  
**INSPECTION REPORT**

1. Name & address of the building : R.S.M Public School at A-34, Gali No-1, Prem Nagar-III, Kirari Suleman Nagar, Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Composition of building : Ground & 02 Upper Floor Only
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 13/03/2026
8. Name of the Inspecting Officers : ADO (Rohini)
9. Name and designation of officers from the building side : Sh. Rahul Saharan (Principal)
10. Year of Construction : 2023
11. Applicant's letter No. : Online e-mail dated 15/01/2026

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV/UBBL Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	Provided	MR
	• Gate width	Directly accessible	Directly accessible	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m each	1.50m & 1.50m (iron)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	NA	NA	NA
f. Door Size	1.20m	1.20m	MR	
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5	<b>Fire Extinguishers.</b>			
	• Total numbers	04nos	Provided	MR
	• Types	ABC/Co2	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

A 9

7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
➤ Head of the pump	40m	Provided	MR	
➤ Power Supply	Required	Provided	MR	
➤ Auto Starting of pump	Required	Provided	MR	
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 LTR	Provided	MR
15	<b>Exit Signage</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/6

17	Standby power supply			
18	Refuge Area.	Required	Provided	MR
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

**Note:- The observations/ shortcomings issued and communicated vide this department letter of even no. F6/DFS/MS/2025/School/845 dated 27/11/2025 have been complied by the management.**

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended for Grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

*C.L. Meena*  
 Signature of the Inspecting Officer  
 Name:- C.L. Meena  
 Designation:- Asst. Div. Officer (Rohini)

*Alkhuswal*  
 DO (NW) *17/03/26*

Recd. m *25/03/26*  
 Dy CFO (WZ)  
 Fr. Director

*KINP*  
*25/03/26*

*27/03/26*

*Dy. CFO (WZ)*

F.T. please.  
*KINP*  
*30/03/26*

*ADO (Rohini)*

As approved, F.T. letter is setup for your signature please.

*DY CFO (WZ)*

*KINP*  
*01/04/26*

*C.L. Meena*  
*31/03/2026*