



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/School/WZ/2025/ 1229

Dated: 06/10/2025

FIRE SAFETY CERTIFICATE

Certified that the Ryan International School, Plot No.G-2, Sec-11, Rohini, Delhi-85, comprised of Ground + 02 upper floors & 02 Store rooms at terrace has already been issued FSC by this department vide letter No. F.6/DFS/Ms/2022/WZ/School/854 dated 04.08.2022. The school building was re-inspected by the officer concerned of this department on 24.09.2025 in the presence of Mrs. Shifali Sharma, (Principal) and found that now school building is comprised of Ground + 03 upper floors deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class 'Group B Educational' (for Ground + 03 upper floors) with effect from 06/10/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/10/2025 at New Delhi by


M.K.Chattopadhyay
Dy.Chief Fire Officer

Copy to:

1. The Principal, Ryan International School, Plot No.G-2, Sec-11, Rohini, Delhi-85
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Ryan International School, Plot No.G-2, Sec-11, Rohini, Delhi-85.
2. Type of Occupancy : Educational
3. Type of Case : Additional/Alternation (**Ground + 03 upper floors**)
4. Details of Previous NOC : (F.6/DFS/MS/2022/WZ/School/854 dated 04.08.22 Previous NOC Gr.+ 2)
5. Fire Safety directives letter No : F.6/DFS/MS/BP/School/2024/171 dated 29.05.2024.
6. Date of inspection : 27.09.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mrs. Shifali Sharma, Principal
9. Year of Construction : 2004, 2022 & 2025
10. Applicant's letter No. : OD No5969 dated 15.09.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.5m	1.55m & 1.6m	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	16nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooters' Location	-NA-	-NA-	-NA-

N/A Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

VA Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

[Handwritten Signature]
25/9/25

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)N/A
Dy.CFO (WZ)

What about ~~staircases~~ fire check doors in staircases as recommended in fire safety directives?

~~ADO (Rohini)~~

[Handwritten Signature]
27/8/25

Sir, it is a low rise- education building and fcd is not required as per nse.

[Handwritten Signature]
29/9/25

~~DCFO (WZ)~~

[Handwritten Signature]
30/8

~~efo - not available
Principal Director~~

Dy. CFO to ~~Secy.~~

~~Dy. CFO (WZ) 02/10/25~~

~~ADO (Rohini)~~

[Handwritten Signature]

FF letter to put up for kind perused and sign. Please.

MC cell *[Handwritten Signature]*

[Handwritten Signature]