



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

c/43



Dated 28/04/25

No. F.6/DFS/MS/School/2025/NDZ/295

To,

The Manager,  
Sai Dream Public School  
D-18/4, Saket Gali, Old Gobind Pura,  
Delhi-110051.

Sub:- Regarding Issuance of Fire Safety Certificate r/o Sai Dream Public School at D-18/4, Saket Gali, Old Gobind Pura, Delhi-110051.

Sir,

With reference to your Outdoor Dairy No. 13077 dated 03/03/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on dated 19/04/2025 of the above mentioned School from fire safety point of view in presence of the Mr. K.L. Malohtra Manager of the school. The building comprised of ground plus three upper floors. Following shortcomings were observed during the time of inspection.

1. Second staircase of width 0.75 meter found removed.
2. First Aid Hose reels at 2<sup>nd</sup> & 3<sup>rd</sup> floor found removed.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned shortcomings under intimation to this office for further course of action.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Director of Education, MCD  
Udyog Sadan, Plot No. 419, FIE, Patparganj Ind. Area, Delhi- 110092