



No.F6/DFS/MS/School/SZ/2025/ 113

Dated: 04/02/2025

FIRE SAFETY CERTIFICATE

Certified that the **Sai Vidya Niketan Public School** located at **D- Block, Hari Nagar Extn. Part-II, Badarpur, New Delhi-44**, comprised of **Ground floor only** was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2017/SZ/1103 dated 16.05.2018. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 30.01.2025 in the presence of Mr. Maharaj Singh Verma (Manager) and found that temporary construction on terrace has been added to the building and school building at ground floor has complied with the fire prevention and fire safety requirements in accordance with the circular no. 262-362 dated 17.01.2005 issued by the Directorate of Education and the school (**Ground floor only**) is fit for occupancy of Group B "**Educational Building**" with effect from 04/02/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on...04/02/2025 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service
dl c

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, Sai Vidya Niketan Public School located at D- Block, Hari Nagar Extn. Part-II, Badarpur, New Delhi-44.

Conditions for the validity of Fire Safety Certificate

1. **This Fire Safety Certificate is valid for Ground floor only and no activity is permissible on the 1st floor temporary construction area.**
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Sai Vidya Niketan Public School located at D- Block, Hari Nagar Extn. Part-II, Badarpur, New Delhi-44.		
2	Building is comprised of	Ground + temporary construction terrace floor. -School running at ground floor only -As per the undertaking submitted by the owner placed on file, No teaching activity shall be done on the temporary construction on the terrace area.		
3	Type of occupancy	Group B –Educational Building (School)		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2017/SZ/1103 dated 16.05.2018		
6	Fire safety direction letter no.	DOE Circular 262-362 dated-17/01/2005		
7	Date of inspection	30.01.2025		
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M. Road)		
9	Name of the designation of officer from the building side	Mr. Maharaj Singh Verma (Manager)		
10	Year of construction	1998		
11	Applicant's letter no.	Email dated 22.01.2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6)	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 m	Provided	MR
B	Gate width	NA	NA	NA
C	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases School on ground floor only			
a	Upper floor	NA	NA	NA
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	NA	NA	NA
b	Basement	NA	NA	NA
C	Protection of exits			
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	NA	NA	NA
E	Width of corridor	NA	NA	NA
F	Door size	1.0 mtrs. (for class room)	1.0 mtrs. (for class room)	MR
3	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	Smoke Management System:			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA

AL

5. Fire Extinguisher:				
A	Total numbers	04 nos.	Provided	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	Required	Provided	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	NA	NA	NA
B	Length of hose reel hose	NA	NA	NA
C	Nozzle diameter	NA	NA	NA
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
8	MOEFA:	NA	NA	NA
9	Public Address System:	NA	NA	NA
10 Automatic Sprinkler System:				
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
11 Internal Hydrants:				
A	Size of riser/down-comer	NA	NA	NA
B	Number of hydrants per floor	NA	NA	NA
C	Hose box	NA	NA	NA
12 Yard Hydrants:				
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13 Pumping Arrangements:				
A Ground level				
a	Discharge of main pump	NA	NA	NA
b	Head of main pump	NA	NA	NA
c	Number of main pumps	NA	NA	NA
d	Jockey pump out put	NA	NA	NA
e	Jockey pump head	NA	NA	NA
f	Standby pump out put	NA	NA	NA
g	Standby pump head	NA	NA	NA
h	Auto starting /manual stopping	NA	NA	NA
i	Pump house access	NA	NA	NA
B Terrace Level				
a	Discharge of pump	NA	NA	NA
b	Head of the pump	NA	NA	NA
c	Power supply	NA	NA	NA
d	Auto starting of pump	NA	NA	NA
14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	NA	NA	NA
15	Exit Signage:	NA	NA	NA

16	Provision of Lifts:				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Firemen's grounding switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply:		NA	NA	NA
18	Refuge Area:				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA
19	Fire Control Room:				
	A	Detector system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	PA system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:		NA		NA

LEGENDS:- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education Circular 262-362 Dated-17/01/2005, the FSC issued vide letter no. F6/DFS/MS/School/2017/SZ/1103 dated 16.05.2018 is recommended to be renewed.

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (M. Road)

DO (SD) No activity shall be allowed in temporary construction area.

ADO (M.R.)

Necessary correction made in the FSC. Resubmitted pls

DO (SD) [Signature] 3/2/25

CFO (MOS) [Signature] 3/21/2025

Director [Signature] 13/4/25