



No. F6/DFS/MS/2025/SZ/ 592

Dated: 04/12/2025

To,

Sh. Avnish Kumar,
(Site In charge).
E-522, Greater Kailash- II,
New Delhi-110048.

Subject: - Regarding issuance of Fire Say Certificate in r/o SAMA Hospital located at Plot No. E-522, Greater Kailash Part -II, Delhi-110048.

Sir,

This has refer to your letter no. nil dated nil received through DFS outdoor diary no. 7720 dated 31/10/2025 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on dated 18/11/2025 in presence of Sh. Avnish Kumar to check the compliance of the shortcoming issued vide letter no. F6/DFS/MS/Institutional/SZ/2025/512 dated 24/10/2025 and observed that the following shortcomings are still not complied.

1. The exit door width of patient room of 1.10 mtr. is provided against the requirement width of 1.25 mtr. Each.
2. Fire check door at lift lobby in basement is not provided.

In view of above, the application for issuance of Fire Safety Certificate is rejected. Further, the occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service