

No. F6/DFS/MS/EH/SZ/2026/61

Dated 03/03/2026

To,

The Commissioner,  
Municipal Corporation of Delhi,  
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s **SAMAVAR** (A Unit of Kashmir Education Culture and Science Society) located at B – 36, Pamposh Enclave, New Delhi – 110048.


Sir,

This has a reference to MCD application No. 2026012901035 dated 30/01/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 21/02/2026 in the presence of Capt. V. S Rawat and observed that building comprised of Basement and Ground floor only, following shortcomings were observed during time of inspection:

1. Fire Check Door found removed some places.
2. Smoke Management system provided but not functional in basement.
3. First-Aid-Hose Reel provided but not functional.
4. MOEFA provided but not functional.
5. Automatic Sprinkler system provided but not functional in basement.
6. Internal Hydrants provided but not functional.
7. Hose box found removed.
8. Terrace fire pump provided but not functional.
9. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
30/26  
(A.K. MALIK)  
Dy. Chief Fire Officer  
Delhi Fire Service  
o/c (w)