

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F6/DFS/MS/2025/WEST ZONE/EH/495

Dated 26/12/2025

To,

The Commissioner (MCD),  
SPM Civic Centre,  
JL Nehru Marg, Delhi-110002

Sub:- Special Drive for surprise inspection in r/o eating houses / restaurants in Delhi from Fire prevention & Fire Safety point of view.

Sir,

As per the office order No. F6/DFS/HQ/2025/2127 dated 10/12/2025, surprise inspection of eating house namely Sambookas Café, at Property No.2530, Ground Floor, Hudson Lane, GTB Nagar Delhi-110009 was conducted by officer of this department on dated 15/12/2025 in the presence of Smt. Shailly Chawla to ascertain the availability & operability of the Fire prevention & Fire Safety measure provided in the building and following observation were made during the time of inspection.

1. Fire pump of capacity 450LPM capacity provided but found not functional.
2. Manually operated electrical Fire Alarm (MOEFA) provided but found not functional.
3. Over Head Tank of 13,000 ltr capacity provided against requirement of 20,000 ltr.

**The above mentioned shortcomings should be complied latest by 15 days (i.e.29/12/2025).**

Keeping in view of above, Fire Safety Certificate issued by this department vide letter F6/DFS/MS/EH/2024/SZ/424 Dated 27/12/2024 to the restaurant will remain suspended until the compliance of the above mentioned shortcomings. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully

*S.K. Dua*  
24/12/25

(S.K. Dua)

Dy. Chief Fire Officer (WZ)

Copy to:-

1. Smt. Shailly Chawla, Sambookas Café, at Property No.2530, Ground Floor, Hudson Lane, GTB Nagar Delhi-110009.