



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001





No. F.6/DFS/MS/EH/2026/SZ/ 295

Dated: 02/04/2026

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Sandoz BBQ** restaurant running at upper ground floor only, in a building comprised of Basement, Stilt, Upper ground + 02 upper floors located at B-1/631, Main Najafgarh Road, Janakpuri, New Delhi-110058, owned/occupied by M/s Sandoz Restaurants Pvt. Ltd, was issued FSC by this department vide letter No. F6/DFS/MS/EH/2023/SZ/146 dated 11/05/2023. The premise was re-inspected by the officer concerned of this department on 24/03/2026 in the presence of Mr. Sumit (Manager) and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the said premise is fit for occupancy class "Assembly Group D" (**Restaurant at upper ground floor only**) with effect from 02/04/2026 for a period up to 31/03/2029 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/04/2026 at New Delhi by

  
(A.K. Malik)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service  


Copy to: -

1. The Commissioner, Municipal Corporation of Delhi, 9<sup>th</sup> Floor, Civic Centre, Minto Road, New Delhi-110002 (w.r.t. online Id. No. 2026031002629 dated 10/03/2026)
2. Authorized Signatory, M/s Sandoz BBQ Restaurant, B-1/631, Main Najafgarh Road, Janakpuri, New Delhi-110058

**Conditions for the validity of Fire Safety Certificate:**

1. This FSC is issued & valid for upper ground floor only.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided there in shall be maintained in good working conditions at all time as seen during inspection.
4. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of fire-fighting system.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
8. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N-8

INSPECTION REPORT				
1.	Name & address of the building	M/s Sandoz BBQ (Sandoz Restaurants Pvt. Ltd) at Prop. No. B-1/631, Upper Ground Floor, Main Najafgarh Road, Janakpuri, New Delhi-110058		
2.	Type of Occupancy	Assembly Group "D" (Eating House).		
3.	Building Comprised of	Basement, Stilt, UG Floor + 02 upper floors. But restaurant is at upper ground floor only.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/EH/2023/SZ/146 Dt. 11/05/2023		
6.	Fire safety directives letter No.	Nil		
7.	Date of inspection	24/03/2026		
8.	Name of the Inspecting Officer	ADO (JKP)		
9.	Name and designation of Officer from the building side	Mr. Sumit (Manager)		
10.	Year of Construction	2001		
11.	Applicant's letter No./Online Appn.	No.2026031002629 dated 10/03/2026		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr	Provided	MR
	• Gate width	N/A	Open to road	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	Restaurant running at UG Floor only		
	• Upper floors	02 Nos	03 Nos	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	2.0m & 1.5m	2 of 1.50m each & 1 of 2m (Iron)	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	2 Nos	Provided	MR
	e. Width of Corridor	1.50 mtr	Opening in hall	MR
	f. Door Size	2.0 & 1.50m	2m, 1.90m & 1.80m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System	Restaurant running at UG Floor only		
	• Basement.	N/A	N/A	N/A
	• Upper floors/Restaurant	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	06 Nos	Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02 Nos	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR

N-9

7.	Automatic fire detection and alarming system.			
	• Type of detector	Smoke	Provided	MR
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	02 Nos	Provided	MR
	• Hose Box	02 Nos	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15	Exit signage	Required	Provided	MR
16.	Provision of lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

8/2

N-10

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/EH/2023/SZ/146 dated 11/05/2023, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, DFA is put up for approval and signature please.

Date of deemed/auto approval is 08/04/2026.

*Santosh Kumar*  
 25/3/26  
 Signature of the Inspecting Officer  
 Name: Santosh Kumar  
 Designation: ADO (JKP)

~~DO (SW)~~

*Rajinder Atwal*  
 26/3/26  
 RAJINDER ATWAL  
 DfS (S2)

*A.K. Malik*  
 27/3/26  
 A.K. MALIK

~~DO (SW)~~  
 Principal Director

my. CFO to *[Signature]*  
 27/03/26

my. CFO (S2)

*A.K. Malik*  
 11/4/26  
 A.K. MALIK

*[Signature]*  
 1/4