



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001




No. F6/DFS/MS/2026/School/WZ/ 138

Dated: 01/09/2026

FIRE SAFETY CERTIFICATE

Certified that the Sangwan Model Secondary School located at Mange Ram Park, Sector-23, Rohini Near Pooth Kalan, Delhi-110086 comprised of Basement, Ground & First Floor owned/ occupied by the Sangwan Model Secondary School have complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 and verified by the officer concerned of Fire Service on 03/08/2026 in the presence of Sh. Pardeep Sangwan and that the building/premises is fit for occupancy **“Group B Educational for ground & first floor only”** with effect from 01/09/2026 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/09/2026 at New Delhi


(A.K. Malik)

Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi – 110085.
2. The Principal, Sangwan Model Secondary School located at Mange Ram Park, Sector-23, Rohini Near Pooth Kalan, Delhi-110086.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form “K”** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form ‘J’** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry”.
8. This Fire Safety Certificate is valid only for ground & first floor and basement not in use as per undertaking by the school management. In case of any violation, this FSC will be treated as null & void

INSPECTION REPORT

1. Name & address of the building : Sangwan Model Secondary School at Mange Ram Park, Sec-23, Rohini Near Pooth Kalan, Delhi-110086.
2. Type of Occupancy : Educational (School)
3. Type of Case : New Case
4. Composition of building : Basement, Ground & First Floor, But School is running at ground & first floor Only & Basement not in use as per undertaking dated 06/08/2026.
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : D.O.E Circular Dated 01.03.2011
7. Date of inspection : 03/08/2026
8. Name of the Inspecting Officers : ADO (Kirari)
9. Name and designation of officers from the building side : Sh. Pardeep Sangwan
10. Year of Construction : 2007
11. Applicant's letter No. : Letter No. Nil & DFS Dairy No-3744 dated 14/07/2026

S.No	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E Circular Dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Directly accessible	Directly accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	05	MR
	• Basements	NA	05	NA
	b. Width of staircases			
	• Upper Floors	1.50m	02 nos. of 1.50m & 1.90m, 01m, 90cm	MR
	• Basements	NA	Basement not in use	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5	Fire Extinguishers.			
	• Total numbers	08nos	Provided	MR
	• Types	ABC/Co2	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	Provided	NA
	• Length of hose reel hose	NA	Provided	NA

	• Nozzle diameter	NA	Provided	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	Basement not in use	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	NA	450 Lpm	NA
	➤ Head of the pump	NA	40m	NA
	➤ Power Supply	NA	Provided	NA
	➤ Auto Starting of pump	NA	Provided	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	NA	15,000 Ltr	NA
15	Exit Signage	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
		N/A	N/A	N/A

N/10

	• Lift Signage			
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, **it is recommended for Grant Fire Safety Certificate.**

Signature of the Inspecting Officer
 Name:-C.L. Meena
 Designation:- Asst. Div. Officer (Kirari)

DO (NW)

Dy Cfo/W2

10/08/2026
 cfo (w2)

10/8/26
 A.K. MALIK

fr. Dir. Cfo to asst. Dir. 12/8

Received on 25/8/26
 Cfo (w2)

25/8/26
 A.K. MALIK

Dy Cfo (w2)

Asst. Dir.

28/08/2026
 Debabrata Mukherjee

Cont.. P.T.O.