




cls



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No. F.6/DFS/MS/EH/2025/SZ/ 470

Dated: 08/12/2025

To,

Sh. Vikram Singh Panwar,
M/s Sankalp Restaurant (A Unit of Sankalp Recreation Pvt. Ltd.)
Plot no. 94, Block B, Pocket-1, Sector-13,
Near Raddison Blu and Metro Station, Dwarka,
New Delhi-110075

Subject: -Regarding renewal of Fire Safety Certificate in r/o M/s Sankalp Restaurant (A Unit of Sankalp Recreation Pvt. Ltd.) situated at Plot no. 94, Block B, Pocket-1, Sector-13, Near Raddison Blu and Metro Station, Dwarka, New Delhi-110075.

Sir,

This has a reference to MCD online application ID No. 2025110614636 dated 18/11/2025 on the subject cited above. In this connection, it is to inform you that officer concerned of this department has visited the premises on dated 29/11/2025 in presence of Mr. Vikram, Manager and observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/EH/SZ/2025/322 dated 31/07/2025 (copy enclosed) have not been complied yet.

In view of above, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Encl. As above

Yours faithfully,


5/12/25
(A. K. MALIK)

DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

The Commissioner, MCD, Civic Centre, New Delhi
MCD online Portal ID-2025110614636

c/34 d54 c/52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/EH/SZ/2025/324

Dated: 31/07/2025

To

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre, New Delhi - 110002.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Sankalp Restaurant (A Unit of Sankalp Recreation Private Limited) located at Plot No. 94, Block-B, Pocket -10, Sector - 13, Near Raddison Blu And Metro Station, Dwarka, Delhi - 110075.

Sir,

This has reference to MCD online application ID No. 2025060909839 dated 03.07.2025 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22.07.2025 in presence of Mr. Vikram Singh (Manager) and it was observed that building is comprised of Basement + Stilt + upper ground + 03 upper floors but restaurant running at upper ground floor only. During inspection, following shortcomings were observed:

1. 02 numbers of exits are provided having width of 1.80 m & 1.20 m against the requirement of 2.0 m & 1.5 m respectively
2. Smoke management system not provided in restaurant area.
3. Fire pump not on auto start mode.
4. Water storage tank capacity of 10,000 ltrs. provided against the requirement of 20,000 ltrs.
5. The second exit opens into the kitchen area, which is not permissible as per UBBL/2016.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


30/07/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service
Tel: 011-23414333

Copy to:-

1. MCD portal ID No. 2025060909839 dated 03.07.2025 for uploading.