



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 26

Dated: 10/01/2025

To

The Principal
Sarvodaya Kanya/Bal Vidyalaya
Bhalswa Village, Burari Swaroop
Nagar Road, Delhi-110042.

Sub: - Regarding renewal of fire safety certificate in r/o Sarvodaya Kanya/Bal Vidyalaya (School ID No-1309280-1309310) located at Bhalswa Village, Burari Swaroop Nagar Road, Delhi-110042.

Sir,

Please refer to your letter received through online e-mail dated 28.12.2024 on the subject cited above. In this connection this is to inform you that the above mention site was visited by the officer concerned of this department on 03.01.2025 in the presence of Smt. Santosh Kumari (Vice-principal) was also present at site to check the existing fire safety & means of escape measures. During inspection it has been observed that the education building is comprised of 05 blocks interconnected, Ground & 03 upper floors each. The observations/ shortcomings made are as under:-

1. Hose reel hose is provided but not functional and some hose reel nozzle found missing.
2. Terrace level fire fighting pumps capacity of 450lpm is provided but not functional.
3. Terrace level fire water tank is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only
4. Exit & floor signage's found removed at strategic locations in the school building.
5. One temporary seating cabin constructed and damaged item storage below in staircase needs to be removed.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.