



C/32

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 242

Dated: 17/04/2025

To

The Principal,
Sarvodaya Bal Vidyalaya,
Sadiq Nagar,
New Delhi-110049

Sub: Inspection report in r/o Sarvodaya Bal Vidyalaya located at Sadiq Nagar, New Delhi (School ID: 1924009)

Sir,

This is with reference to your letter No. SBV/SN/2024-25/216 dated 04/01/2025 received through outdoor diary No. 11191 dated 08.01.2025. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department from fire safety point of view on 02/04/2025 in your presence. During course of inspection, the shortcomings observed are as below.

1. The hose-reel hoses found provided but non-functional.
2. Terrace level fire pump was not on auto mode.
3. Overhead water storage tank exclusively for firefighting found empty.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

16/04/2025
(Virendra Singh)
Chief Fire Officer
Ph. 011-23414333
ofc 82

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.