



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2026/SZ/08

Dated: 09/01/2026

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Bal Vidyalaya** located at Subhash Nagar, New Delhi-110027 (School ID: 1515003), having three blocks, comprised of (A Blk) Ground Floor (B Blk) Ground + 01 upper floor and (C Blk) Ground + 03 upper floors and a separate hall at ground floor only, owned/occupied by Directorate of Education, Govt. of NCT of Delhi, was issued FSC by this department vide letter No. F6/DFS/MS/School/SZ/2022/338 dated 29/03/2022 (for C Blk) and F.6/DFS/MS/School/2022/SZ/898 dated 17/08/2022 (for A&B Blk). The premise was re-inspected by the officer concerned of this department on 26/12/2025 in the presence of Sh. Manoj Kumar (Principal) and found to have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular dated 01.03.2011 and Rule 33 of the Delhi Fire Service Rules, 2010 and that the school premise/building is fit for occupancy class "Educational Group B-1" with effect from 09/01/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/01/2026 at New Delhi by

(A.K. Malik)

Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. The Principal, Sarvodaya Bal Vidyalaya, Subhash Nagar, New Delhi-110027 (ID: 1515003)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL -2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-29

INSPECTION REPORT			
1.	Name & address of the building	Sarovodaya Bal Vidyalaya, Subhash Nagar, New Delhi-110027 (ID: 1515003)	
2.	Type of Occupancy	Educational (Group B-1)	
3.	Building Comprised of	03 Blocks namely A-Blk (GF only), B-Blk (G+1) & C-Blk (G+3 & separate hall at GF).	
4.	Type of Case	Renewal	
5.	Details of previous FSC No.	F.6/DFS/MS/School/SZ/2022/338 dt. 29/03/22 (C-Blk) F.6/DFS/MS/School/2022/SZ/898 dt. 17/08/22 (A&B)	
6.	Fire safety directives letter No.	DOE Circular No. 3298 to 3398 Dated 01.03.2011	
7.	Date of inspection	26/12/2025	
8.	Name of the Inspecting Officer	ADO (JKP)	
9.	Name and designation of Officer from the building side	Sh. Manoj Kumar (Principal)	
10.	Year of Construction	A-Blk-1954, B-Blk-2009 & C-Blk-2022	
11.	Applicant's letter No.	SBV/SN/2025-26/341 dated 12/12/2025 received through Diary No. 1404/PD Dated 23/12/2025	
S. No.	Minimum standards on fire prevention and fire safety U/R 33	OLD FSC Requirement	Provided at site Remarks MR/NMR
1.	Access of building		
	• Road width	6.0 mtr	Provided MR
	• Gate width	4.5 mtr	4.5 mtr MR
	• Width of internal road	N/A	N/A N/A
2.	Number, width, Type & Arrangements of exits		
	a. Number of staircases		
	• Upper floors	2 Nos (C Blk)	2 Nos (C Blk) MR
	• Basements	3 Nos (B Blk)	3 Nos (B Blk) N/A
		N/A	N/A
	b. Width of staircases		
	• Upper floors	1.50m each	1.80m x 2 (C Blk) 1.50m x 3 (B Blk) MR
	• Basements	N/A	N/A N/A
	c. Protection of exits		
	• Fire check door	N/A	N/A N/A
	• Pressurization	N/A	N/A
	d. No of continuous staircase to terrace	02 in C Blk	Provided MR
	e. Width of Corridor	1.5m in C Blk	1.80 mtr in C Blk MR
	f. Door Size	1.2m (C Blk) & In Hall 1.0m (A&B)	1.22m x 2 in each (C Blk) Hall: 1.20-2.10m (total 08) 0.90, 0.95, 1.10m & 1.0m MR
3.	Compartmentation		
	• Fire check door	N/A	N/A N/A
	• Sealing of electrical shafts	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A
	• Water Curtain	N/A	N/A
	• Fire Dampers	N/A	N/A
4.	Smoke Managements System		
	• Basements	N/A	N/A N/A
	• Upper floors	Required	Natural ventilation MR
5.	Fire Extinguishers		
	• Total numbers	Portable Fire Extinguishers	42 Nos MR
	• Types	ISI marked	ABC & CO ₂ MR
	• ISI marking		Provided MR
6.	First-Aid Hose Reels		
	• Total numbers on each floor	03 (C Blk)	Provided MR
	• Length of hose reel hose	30 mtr	Provided MR
	• Nozzle diameter	05 mm	Provided MR

SR

7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM (In C Blk only)	450 LPM x 2 (In C Blk only)	MR
	➤ Head of the pump	40m	40m each	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 lts	10,000 lts	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building/premises (New Block only) were checked, tested at random and **found functional at the time of inspection**. The shortcomings issued by this department vide letter No. F6/DFS/MS/School/2025/SZ/390 dated 14/05/2025 found rectified.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the DOE Circular/Rules, the fire safety certificate issued vide letter No. F6/DFS/MS/School/SZ/2022/338 dated 29/03/2022 (for C Block) and F.6/DFS/MS/School/2022/SZ/898 dated 17/08/2022 (for A & B Block), **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended for all the three blocks.**

Accordingly, **DFA is put up for approval & signature please.**

Santosh Kumar
10/11/2026

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (JKP)

~~DO (SW)~~

[Signature]
11/1/26
RAJINDER ATWAL
Dy. C.O. (SZ)

[Signature]
11/1/26
A.K. MALIK
Principal Director

[Signature]
My. C.O. to Inspr.
02/01/26

[Signature]
My. C.O. (SZ)

[Signature]
5/1/26
DO (SW) *[Signature]*
ADDO (JKP) SK

P150