



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001




No. F6/DFS/MS/2025/School/ 1092

Dated: 02/09/2025

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Co-ed Vidyalaya No-1 (School ID No-1207037) located at Shakti Nagar, Delhi-110007, comprised of 06 blocks interconnected, 02 blocks comprised of Ground + first floor & 04 blocks comprised of Ground + 02 upper floors only owned/ occupied by Sarvodaya Co-ed Vidyalaya No-1 was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/School/WZ/2014/847 dated: 10.07.2014 for 03 blocks- 1st block, Ground+02 upper floors, 2nd block- ground + first floor & 3rd block, ground floor pota cabin only. The school premises was re-inspected by the officer concerned of this department on 13/08/2025 in the presence of Smt. Manju Meena and observed that the school management has added three more blocks interconnected with old blocks and all the fire prevention and fire safety arrangements as provided in the school building found in good working condition. The premise have therefore complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premises is fit for occupancy under "Educational Group B (School)" with effect from ... 02.09.2025 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 02/09/2025 at New Delhi


Virendra Singh
Chief Fire officer
Delhi Fire Service
9c 6y

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. Sarvodaya Co-ed Vidyalaya No-1 located at Shakti Nagar, Delhi-110007.

Conditions for the validity of Fire Safety Certificate:

1. Multipurpose Hall at ground floor shall not be used for any purpose.
2. All the means of escape shall be kept free from any type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
4. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
6. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
7. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Co-ed Vidyalaya No-1 at Shakti Nagar, Delhi-07.
2. Composition of building : 06 blocks interconnected 02 blocks, (Ground + first floor & 04 blocks, Ground + 02 upper floors only
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of previous NOC : F6/DFS/MS/School/WZ/2014/847 dated: 10.07.2014, 03 blocks- 1 block, Ground+ 02 upper floors, 2nd block- ground + first floor & 3rd block ground floor pota cabin
6. Fire Safety directives letter No : Nil
7. Date of inspection : 13/08/2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
From the building side : Smt. Manju Meena
10. Year of Construction : 1957, 1969, 1989 & 2021
11. Applicant's letter No. : Letter No- SV/CO-ED/SN1/2025/447 Dated 24/07/2025

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	12m	MR
	• Gate width	4.50m	06m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	07	07	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m each, 03 nos. of 1.40m & 1.25m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	1.50m	2.40m	MR
	f. Door Size	01m	01m double door	MR
3	Compartmentation.			
	• Fire check door *	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	26nos	50nos	MR
	• Types	ABC/Co2	ABC-40, Co2-08 & water mist- 02	MR
	• ISI marking	Yes	Provided	MR


N/22

6	First-Aid Hose Reels.			
	• Total numbers on each floor	05 at each floor	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM Each	Provided	MR
	➤ Head of the pump	40m	Provided	MR
➤ Power Supply	Required	Provided	MR	
➤ Auto Starting of pump	Required	Provided	MR	
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 LTR	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
16	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
	N/A	N/A	N/A	


18	Refuge Area.	➤ Total Area	N/A	N/A	N/A
		➤ Location	N/A	N/A	N/A
19	Fire Control Room	• Detector System Panel	N/A	N/A	N/A
		• Flow Switch Panel	N/A	N/A	N/A
		• PA System Panel	N/A	N/A	N/A
		• Batter backup	N/A	N/A	N/A
		• Building Floor Plans	N/A	N/A	N/A
		Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2024/School/841 dated 24/12/2024.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by NBC Part-IV, **it is recommended for Grant of Fire Safety Certificate.**



 Signature of the Inspecting Officer
 Name:- C.L. Meena
 Designation:- Asst. Div. Officer (RN)

D.B. Mukharjee (DO/NW)


 25/08/2025
 Dy CFO (NW)



 26/8

DCFO/... 357/MS
 Dated... 26/8/2025


 27/8/2025
 Principal Director

CFO to Issue


 28/08/25


 29/8/2025


 ADD (RN)

cont... P.T.O.