

No. F.6/DFS/MS/WZ/School/2025/155

Dated 14/02/2025

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya kanya Vidyalaya, located at Moti Nagar, New Delhi – 110015. (School ID-1516018) comprised of ground and three upper floors, was already issued FSC vide letter No.F6/DFS/MS/School/WZ/2022/140 dated 10/02/2022, Owned/occupied by Sarvodaya kanya Vidyalaya. The premises was re-inspected by officer concerned of this department on 04/02/2025 in the presence of Sh. Kusum Lata (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules 2010. The premises have therefore complied with Director of Education Circular No. 3298-3398 dated 13/11/2024/NBC (Part-IV) and that the building/premises is fit for occupancy class "Educational" Group-B,(Ground and three upper floors block only) with effect from14/02/2025...for a period of three years and subject to the conditions mentioned below.

Issued on 14/02/2025 at New Delhi by

(Anul Garg)
Director
o/c 884
13/2/2025

Copy to: -

1. The principal/Incharge, Sarvodaya kanya Vidyalaya , located at Moti Nagar, New Delhi – 110015.(School ID-1516018) Email:-skv.motinagar@gmail.com
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building	Sarvodaya Kanya Vidyalaya, Moti Nagar, New Delhi - 110015.(School ID-1516018)
2. Type of Occupancy	Educational (G + 03 upper floors)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/School/WZ/2022/140 dated 10/02/2022 (For G+3)
5. Fire Safety directives letter No	Nil
6. Date of inspection	04/02/2025
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh Kusum Lata (Principal)
9. Year of Construction	2021 (As per Prev. Insp. report dtd.- 28/01/2021 (G+3))
10. Applicant's letter No.	Outdoor Diary No. - 9587 dated 26/11/2024

The said School is running in ground and three upper floors, was already issued FSC vide letter No. F6/DFS/MS/School/WZ/2022/140 dated 10/02/2022 (For G+3)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
--------	---	---	------------------	----------------

1	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA

2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mts each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	1.5m	Provided	MR
	g. Door Size	2X1.20m	Provided	MR

3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

5	Fire Extinguishers			
	• Total numbers	12 Nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	02	NA	NA
	• Length of hose reel hose	30m	NA	NA
	• Nozzle diameter	5mm	NA	NA

117

7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
		NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000ltrs	Provided	MR
15	Exit Signage.			
		Required	MR	Provided
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply			
		NA	NA	NA

18	Refuge Area. M14			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:			
		NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2022/140 dated 10/02/2022, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

ADY (120/W12)

SSP
06/12/25

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

ADO/MN
12/2025

[Signature]
10/12/2025

CFD
[Signature]
11/21/2025

4-2025...
10/12/2025

Director
[Signature]
11/20/25

M/LL

Sir, F.T is put up for your kind personal & Signature please.

[Signature]
18/12/2025

Director
[Signature]
13/12/25