


FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya, (New Block) (ID-1515021), located at Rajouri Garden Extension, New Delhi – 110027, comprised of Ground Floor + 03 Upper Floors, owned/Occupied by Sarvodaya Kanya Vidyalaya, was issued FSC vide letter No F6/DFS/MS/School/2022/SZ/515 dated 12/05/2022. The premises was re - inspected by the officer concerned by this department on 28/01/2025, in the presence of Smt. Mamta Oberoi (HOS) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules 2010 and found that the building / premises is fit for the occupancy class "Educational" Group B(Ground plus three upper floors block only) with effect from ..07/02/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on07/02/2025 at New Delhi.


(Atul Garg)
Director
ie 06/02/2025

Copy to:

1. The Principal, Sarvodaya Kanya Vidyalaya, (School ID-1515021) (New Block) located at Rajouri Garden Extension, New Delhi – 110063. Email ID:- 1515021z15@gmail.com.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

r/w
INSPECTION REPORT

1.	Name & address of the building	Sarvodaya Kanya Vidyalaya, Located at Rajouri Garden Extension, New Delhi - 110063.(School ID-1515021)
2.	Type of Occupancy	Educational(Ground Floor + 03 Upper Floor)(New Block)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/School/2022/SZ/515 dated 12/05/2022.
5.	Fire Safety directives letter No	Nil
6.	Date of inspection	28/01/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Ms. Sunita Kumari (HOS) Sh. Arun Kumar Singh (Estate Manager)
9.	Year of Construction	2018-22 (As per previous Inspection Report)
10.	Applicant's letter No.	Email dated 16/01/2025.

The said school building comprised of Ground + 3 Upper Floor (New Block) was issued FSC vide letter no. F6/DFS/MS/School/2022/SZ/515 dated 12/05/2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04 nos.	04 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50 m each	2x1.8 & 2x1.7 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02 nos.	02 Provided	MR
	e. Width of Corridor	1.5 m	1.7 m Provided	MR
	f. Door Size	1.20 m	2x1.20 m Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR

7	Automatic fire detection and alarming system.			NA
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			NA
9	Public Address System.			NA
10	Automatic Sprinkler System.			NA
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			NA
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	2x900LPM Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	10,000 ltrs Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply			NA
18	Refuge Area.			NA
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA

Fire Control Room			
	• Detector System Panel	NA	NA
	• Flow Switch Panel	NA	NA
	• PA System Panel	NA	NA
	• Battery backup	NA	NA
	• Building Floor Plans	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/2022/SZ/515 dated 12/05/2022, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

~~Dy CPO (W/2)~~

~~Signature~~
30/1/2025

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

20/MN
1/2025

~~Signature~~
21/2/2025

~~CFO~~
~~Signature~~
4/2/2025
~~Director~~
~~Signature~~
2/2/25

~~Signature~~ Sir, F.T is

put up for your kind personal & signature
plz

~~Discharge~~
~~Signature~~
6/2/25

~~Signature~~
06/02/2025

✓

20.11.2025
20/1/2025