

C48

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/School/SZ/2025/1375

Dated: 03/12/2025

FIRE SAFETY CERTIFICATE

Certified that Sarvodaya Kanya Vidyalaya at Shadi Khampur, New Delhi- 110008, having 05 Blocks namely block 1, 2, 3 & 4. Block-1 is comprised ground plus one upper floor, Block-2 is comprised of ground plus two upper floors are interconnected, Block-3 & Block-4 are comprised of ground plus one upper floors, Block 01 to 04 was issued FSC vide letter No. F.6/DFS/MS/School/SZ/2022/1334 date 15.12.2022 & Block- 05 comprised of ground plus three upper floors was issued separate FSC vide letter No. F.6/DFS/MS/School/SZ/2023/353 dated 25.05.2023. The school building was re-inspected by the officer concerned of Delhi Fire Service on dated 19.11.2025 in the presence of Mrs. Rajni Gupta (Principal)), and found that the school management have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Act 2007 and Rules 2010 and that the building/premises is fit for occupancy class "Educational Building" (Block – 01 to 05), w.e.f. 03/12/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below

Issued on 03/12/2025 at New Delhi by.


 11/12/25
 (A.K. Malik)
 Dy. Chief Fire Officer
 South Zone

Copy to: -

1. The Principal, Sarvodaya Kanya Vidyalaya at Shadi Khampur, New Delhi- 110008.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 54.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, Shadi Khampur, New Delhi- 08.
2. Type of Occupancy : Educational
3. Building Composition : having 05 blocks, namely block 1,2,3,4 & 5 block, Blk-1 (G+1), Blk-2 (G+2), Blk-3 & 4 (G+2) & Blk- 05 (G+3). Blk-1 & 2 are interconnected to each other.
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/School/SZ/2022/1334 date 15.12.2022 (for Blk- 1,2,3 & 4) & F.6/DFS/MS/School/SZ/2023/353 dated 25.05.2023 (for 01 Blk-5, G+3 UFs)
6. Fire Safety directives letter No : Nil
7. Date of inspection : 19.11.2025
8. Name of the Inspecting Officers : R.K. Yadav, Asstt. Div. Officer (SRD)
9. Name and designation of officers from the building side : Ms. Rajni Gupta (HOS)
9. Year of Construction : 1987 & 2022 (Blk- 5, G+3 UFs)
10. Applicant's letter No. : SKV/SKP/2025/313 dated 14.10.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	3.6 mts	MR being old case
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02 at each blk	Blk- 1 & 2- 02 nos., Blk-3- 01 nos., Blk- 4- 02 nos. & Blk-5- 01 nos.	MR, old case
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts or less & 0.75 mt	Blk- 1 & 2- 1.30 & 1.26 m, Blk-3- 1.53 m, Blk- 4- 1.55 & 1.53 m & Blk-5- 1.78 m	MR, old case
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01 each block	Provided	MR
	g. Width of Corridor	1.50 m	Provided	MR
	h. Door Size	1.0 m.	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour (N/A)	N/A	N/A
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	35 nos.	Provided	MR
	• Types	ABC, CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR

N/34

6	First-Aid Hose Reels.			
	• Total numbers on each floor	02 Nos.	Provided in block 1, 2 & 5	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided in block 1, 2 & 5	MR
	• Number of hydrants per floor	02 nos.	Provided	MR
	• Hose Box	02 nos.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level	---	-----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	450 LPM at Blk- 02 & 05	450 LPM x 02 nos (Blk- 1 & 2) & 450 LPM x 02 nos (Blk- 5)	MR
	➤ Head of the pump	40 mts	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 lts	10,000 lts (Blk- 1 & 2) 10,000 lts (Blk- 5)	MR
		Required	Provided	MR
	Exit Signage.			
	Provision of Lifts.			

N/35

	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers are provided near elect. Panel.	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/SZ/2022/1334 date 15.12.2022 (for Block- 01, 02, 03 & 04) & F.6/DFS/MS/School/SZ/2023/353 dated 25.05.2023 (for Block- 05, G+3 UFs), is recommended to be renewed, under rule 37, of the Delhi Fire Service Rules, 2010.

R.K. Yadav
 Signature of the Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (DWK)

DO (SW)
R.A.
 21/11/25
 RAJINDER ATWAL
 Dy. CFO (SZ)

Anilak
 24/11/25
 A.K. MALIK

Principal Director

Dy. CFO to Insp.

26/11/25

Dy. CFO (SZ)

Anilak
 27/11/25
 A.K. MALIK

DO (SW)
27/11
 ADO (SW)

PFO