

c/36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/ 476

Dated: 06/06/2025

To,

The Principal,
Sarvodaya Kanya Vidyalaya,
Uttam Nagar, New Delhi-110059.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Sarvodaya Kanya Vidyalaya at Uttam Nagar, New Delhi-110059.


Sir,

Please refer to your letter No. SKV Uttam Ngr/2025-26/69 dated 29.04.2025, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on dated 28.05.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Surender Kumar (Guard), was present and it was observed that the school having two blocks, namely A & B Block (each block comprised of ground plus three upper floors), and have following shortcomings: -

1. Hose reels/hydrant found provided but not functional.
2. Terrace fire pump of 450 LPM × 2 found provided but not functional.
3. Exit signage's are found removed at some place

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully



(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

