



FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya / Sarvodaya Bal Vidyalaya No. 2 (New SPS) located at Mandawali, Delhi - 110092, comprised of ground plus three upper floors owned/occupied by Sarvodaya Kanya Vidyalaya / Sarvodaya Bal Vidyalaya No. 2 have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 15/01/2025 in the presence of Mrs. Priya Malik (Vice-Principal) and observed that all the fire prevention and fire safety requirements provided in the premises found in good working condition. and that the school building is fit for occupancy class B "Educational Building" with effect from 24/01/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 24/01/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. Assistant Engineer (E), PWD, Sub Division-4, Edu. Elect. Edn.-1, Rama Road, Zakhira, Delhi - 110015.
2. The Director of Education, MCD, Udyog Sadan, Plot no.419, FIE, Patparganj Industrial Area, Delhi- 110092.
3. The Principal, Sarvodaya Kanya Vidyalaya No. 2 (New SPS) located at Mandawali, Delhi -110092.
4. The Principal, Sarvodaya Bal Vidyalaya No. 2 (New SPS) located at Mandawali, Delhi -110092.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

01.	Name & address of the building	Sarvodaya Kanya Vidyalaya / Sarvodaya Bal Vidyalaya No. 2 (New SPS) located at Mandawali, Delhi - 110092.				
02.	Building is comprised of	Ground plus three upper floors				
03.	Type of occupancy	Educational Building				
04.	Type of case	New Case				
05.	Details of previous FSC	NIL				
06.	Fire safety directives letter no.	NBC Part - IV				
07.	Date of inspection	15/01/2025				
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)				
09.	Name of the designation of officer from the building side	Mrs. Priya Malik (Vice-Principal)				
10.	Year of construction	2021				
11.	Applicant's letter no.	Email dated 14/01/2025 & Outdoor Diary No. 9514 dated 25/11/2024				
S. No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part - IV Requirement	Provided at site	Remarks MR/NMR		
01.	Access to Building:					
	A	Road width	6.0 meters.	6.0 meters.	MR	
	B	Gate width	NA	NA	NA	
	C	Width of internal road	NA	NA	NA	
02.	Number, Width, Type and Arrangement of Exits:					
	A	Number of staircases				
		a	Upper floor	04 nos.	04 nos.	MR
		b	Basement	NA	NA	NA
		B	Width of staircases			
		a	Upper floor	1.50 meters each	1.50 meters each	MR
		b	Basement	NA	NA	NA
		C	Protection of exits			
		a	Fire check door	NA	NA	NA
		b	Pressurization	NA	NA	NA
		D	No. of continuous staircases to terrace	03 nos.	05 nos.	MR
		E	Width of corridor	1.50 meters.	1.82 meters.	MR
		F	Door size & No. of Doors	1.20 meters x 02 nos.	1.20 meters x 02 nos.	MR
	03.	Compartmentation:				
A		Fire check door	NA	NA	NA	
B		Sealing of electrical shafts	NA	NA	NA	
C		Fire rating of shaft door	NA	NA	NA	
D		Water curtain	NA	NA	NA	
E		Fire dampers	NA	NA	NA	
04.	Smoke Management System:					
	A	Basement	NA	NA	NA	
	B	Upper floor	NA	NA	NA	

W A

05.	Fire Extinguisher:				
	A	Total numbers	18 nos.	40 nos.	MR
	B	Types	ABC/CO ₂	ABC/CO ₂	MR
	C	ISI marking	ISI marked	ISI marked	MR
06.	First-Aid-Hose Reel:				
	A	Total numbers of each floor	04 nos.	05 nos.	MR
	B	Length of hose reel hose	30 mtrs	30 mtrs	MR
	C	Nozzle diameter	05 mm	05 mm	MR
07.	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
08.	MOEFA:				
09	Public Address System:				
10.	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12.	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13.	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 LPM	450 LPM x 02 nos.	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Required	MR
	D	Auto starting of pump	Required	Required	MR


7/24

Sarvodaya Kanya / Bal Vidyalaya No. 2 (New SPS) located at Mandawali, Delhi -110092.

14. Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	10,000 liters	20,000 liters	MR
E	Overhead tank capacity	Required	Provided	MR
15. Exit Signage:				
16. Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17. Standby Power Supply:				
18. Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19. Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20. Special Fire Protection systems for protection of special Risks, if any:				

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections. The shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2024/641 dated 19/09/2024 has been rectified.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended. No file is pending with me before disposal of this case.


17/11/2025


Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO/Laxmi Nagar

~~D.O/EAST~~


20/01/25


~~Dy. CFO (NDZ)~~


20/01/25

~~C.FO~~

21/01/2025

~~Director~~

22/11/25


P.T.O