



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 349

Dated: 07/05/2025

To

The Principal
Sarvodaya Co-ed Vidyalaya
at Gulabi Bagh, Delhi-110007.

Sub: -Regarding issuance of fire safety certificate in r/o Sarvodaya Ce-ed Vidyalaya (School ID No. 1208013-128001) at Gulabi Bagh, Delhi-110007.

Sir,

Please refer to your letter No. S.Co-ed.V/GB/2025/203 dated: 23/04/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 03/05/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 03 blocks, A & B- blocks interconnected comprised of ground + 03 upper floors & C- block comprised of ground + first floor only. At the time of inspection Sh. Atit Saini was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire extinguisher is provided but found not functional at the time of inspection.
2. Hose reel hose is provided but not functional.
3. Terrace level fire pump capacity of 450lpm each is provided but not functional.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Gang)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054