



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

(-37)
FIRE SERVICE
DELHI

No. F.6/DFS/MS/School/2025/NDZ/ 278

Dated 25/04/2025

To,

The Principal,
Govt. Sarvodaya Kanya Vidyalaya,
Gokal Puri, Delhi-110094

Sub:- Regarding Issuance of Fire Safety Certificate r/o Govt. Sarvodaya Kanya Vidyalaya, Gokal Puri, Delhi-110094.

Sir,

With reference to your letter no. SKV/GP/2025/1073 dated 11/03/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on dated 15/04/2025 of the above mentioned School from fire safety point of view in presence of the Principal of the school. The building comprised of three blocks, One Block (Ground plus three floors) & other two blocks (ground plus first floor only). Following shortcomings were observed during the time of inspection.

1. Only 07 fire extinguishers provided in place of 16 fire extinguishers as required.
2. Hose reels not provided at each floor as required.
3. A fire pump having 450 LPM output at 40 meters head not provided.
4. Over Head water storage tank 10,000 liters capacity not provided at terrace.
5. Exit Signage not provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned shortcomings under intimation to this office for further course of action.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education
B-Block, Yamuna Vihar, Delhi-110053