

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI** C-28  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2025/SZ/80

Dated: 30/01/2025

To,

The Principal,  
Sarvodaya Kanya Vidyalaya No.-1,  
C-Block, Janakpuri, New Delhi-110058.

**Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o Sarvodaya Kanya Vidyalaya No.-1 at C-Block, Janakpuri, New Delhi-110058.**

Sir,

Please refer to your letter No. SKV/No.1/C-BLK/JP/EM/2024/731 dated 20.12.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 20.01.2025 in the presence of Sh. Rajesh Kumar Gill (Estate Manager), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school building having four blocks namely A block comprised of ground plus two upper floors & B, C and D blocks is comprised of ground plus one upper floor only and following shortcomings were observed: -

1. Hose reels/hydrant found provided but not functional in A Block.
2. Terrace Fire pump capacity of 450 LPM (02 nos.) found provided but not functional in A Block.
3. Exit signage's are found removed at some places.

In view of the above, fire safety certificate cannot be considered at this stage. Therefore, you are requested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy for information: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.