



C/87

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/WZ/2026/49

Dated: 14./01./2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Satyam Guest House, 06, Bhera Enclave, Paschim Vihar, New Delhi - 110087.


Sir,

This has reference to online application received through MCD online portal vide ID No. 2025021101718 dated 16/12/2025 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 24/12/2025 in the presence of Sh. Subhash Bajaj (Owner) and following shortcomings were observed: -

1. Fire Check doors were found removed at some places.
2. Carbon Monoxide detectors were not provided.
3. Manual Operated Electronic Fire Alarm (MOEFA) provided but found non-functional.
4. Automatic operation of Fire pump found removed.


Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


14/01/26

(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to: -

1. The Manager, M/s Satyam Guest House, 06, Bhera Enclave, Paschim Vihar, New Delhi - 110087.