



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F6/DFS/MS/2025/WEST ZONE/ EH/494

Dated 26/12/2025

To,

The Commissioner (MCD),  
SPM Civic Centre,  
JL Nehru Marg, Delhi-110002

Sub:- Special Drive for surprise inspection in r/o eating houses / restaurants in Delhi from Fire prevention & Fire Safety point of view.

Sir,

As per the office order No. F6/DFS/HQ/2025/2127 dated 10/12/2025, surprise inspection of eating house namely Sazy Bear (A unit of Mad Food & Beverages LLP) at 2648, 2<sup>nd</sup> & 3<sup>rd</sup> Floor, Hudson Lane, GTB Nagar Delhi-110009 was conducted by officer of this department on dated 15/12/2025 in the presence of Sh. Deepak (Manager) to ascertain the availability & operability of the Fire prevention & Fire Safety measure provided in the building and following observation were made during the time of inspection.

1. Alternative Fire pump (Diesel operated fire pump) of capacity 2280LPM found removed.
2. Main Pump of capacity 2280 LPM (Electrical) and a jockey of 180LPM and a terrace pump of capacity 450LPM were provided but found nonfunctional.
3. Hose reel hose, Internal hydrants & MOEFA were provided but found nonfunctional.
4. Exit Signages found removed.
5. Automatic sprinkler system provided but also found nonfunctional.

**The above-mentioned shortcomings should be complied latest by 30 days (i.e.14/01/2026).**

Keeping in view of above, Fire Safety Certificate issued by this department vide letter F6/DFS/MS/EH/2024/330 Dated 14/10/2024 to the **restaurant will remain suspended** until the compliance of the above mentioned shortcomings. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully

  
24/12/25

(S.K. Dua)

Dy. Chief Fire Officer (WZ)

Copy to:-

1. Sh. Deepak (Manager), Sazy Bear (A unit of Mad Food & Beverages LLP) at 2648, 2<sup>nd</sup> & 3<sup>rd</sup> Floor, Hudson Lane, GTB Nagar Delhi-110009.