



No. F.6/DFS/MS/School/2026/SZ/21

Dated: 09/02/2026

C 23

FIRE SAFETY CERTIFICATE

Certified that the **M.C. Primary Boys School**, Jharoda Kalan, New Delhi-110072 (School ID: 1757146), comprised of Ground + 01 upper floor, owned/occupied by MCD, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2022/SZ/1198 dated 31/10/2022. The premise was re-inspected by the officer concerned of this department on 21/01/2026 in the presence of Smt. Kusum (Principal) and found that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school premise/building is fit for occupancy class "Educational Group B" with effect from 09/02/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/02/2026 at New Delhi by


6/2/26
(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service
8/1/26

Copy to: -

1. The Director of Education, MCD, Civic Centre, Minto Road, New Delhi-110002
2. The Principal, M.C. Primary Boys School, Jharoda Kalan, New Delhi-110072

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-16

INSPECTION REPORT

1.	Name & address of the building	M.C. Primary Boys School, Jharoda Kalan, New Delhi-110072 (School ID: 1757146)		
2.	Type of Occupancy	Educational (Group B)		
3.	Building Comprised of	Ground + 01 upper floor		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/School/2022/SZ/1198 Dt. 31/10/2022		
6.	Fire safety directives letter No.	DOE Circular No. 3298 to 3398 Dated 01/03/2011		
7.	Date of inspection	21/01/2026		
8.	Name of the Inspecting Officer	ADO (JKP)		
9.	Name and designation of Officer from the building side	Smt. Kusum (Principal)		
10.	Year of Construction	2005-06		
11.	Applicant's letter No.	Outdoor Diary No. 8510 dated 19/11/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6.0 mtr	12 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01 No	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 m	1.64 m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of Corridor	1.50 m	2.20 m	MR
	f. Door Size	1.0 mtr	1.10m (Double Doors)	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	05 Nos	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A

SK

N-17

7.	Automatic fire detection and alarming system	N/A	N/A	N/A
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

JK

N-18

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under DOE Circular dated 01/03/2011, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/2022/SZ/1198 dated 31/10/2022, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, DFA is put up for approval & signature please.

Suman
20.01.26
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (JKP)

~~DO (SW)~~

[Signature]
2/2/26
RAJINDER ATWAL
DCFS (SZ)

[Signature]
2/2/26
A.K. MALIK
Principal

My. CFS to *[Signature]*
[Signature]
20/1/26

~~My CFS (SZ)~~

[Signature]
4/2/26
A.K. MALIK
DO (SW) *[Signature]*
4/2
Adm (JKP)

P.T.O