




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6/DFS/MS/School/WZ/2025/ 1228

Dated: 06/10/2025

FIRE SAFETY CERTIFICATE

Certified that the S. D. Saraswati Bal Mandir, C-5, Rajiv Nagar, Ph-II, (Sec-22, Rohini), Delhi-86, comprised of Ground + 02 upper floors owned/ occupied by the S. D. Saraswati Bal Mandir was granted fire safety certificate vide this office letter no. F.6/DFS/MS/School/WZ/2022/1014 dated 15.09.2022 have deemed complied with the fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 18.09.2025 in the presence of Mrs. Ruchi, (Principal) and that the building/premises is fit for occupancy Group B Educational with effect from 06/10/2025 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/10/2025 at New Delhi by

M. K Chattopadhyay
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Director of Education, Old Secretariat, Delhi.
2. The Manager, S.D. Saraswati Bal Mandir, C-5, Rajiv Nagar, Ph-II,(Sec-22, Rohini), Delhi-86

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : S.D. Saraswati Bal Mandir, C-5, Rajiv Nagar, Phase -II ,
(Sector-22, Rohini), Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Ground + 02 floor**)
4. Details of previous NOC : F.6/DFS/MS/School/WZ/2022/1014 dated 15.09.2022.
5. Fire Safety directives letter No : NBC Part- 4
6. Date of inspection : 25.09.2025
7. Name of the Inspecting Officers : A.K.Sharma ADO (Rohini)
8. Name and designation of officers
from the building side : Mrs. Ruchi (Principal)
9. Year of Construction : 1994
10. Applicant's letter No. : Online e-mail dated 03.09.2025

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6m	MR
	• Gate width	4.50m	3.65m	MR(Old case)
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floors	1.50 m	1.50m & 1.60m	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	02nos.	Provided	MR
	e. Width of Corridor	Required	2.14m	MR
	f. Door Size	1.0m	1.0m	MR
3	Compartmentation.			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4	Smoke Management System.			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	12nos	15 nos.	MR
	• Types	ABC/Co2	Provided	MR
	• ISI marking	ISI marked	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	02nos.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7	Automatic fire detection and alarming system			
			Provided	MR

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8	MOEFA	-NA-	-NA-	-NA-
9	Public Address System.	-NA-	-NA-	-NA-
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm	100mm	MR
		01nos.	Provided	MR
		01nos.	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		450lpm	450 lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		10,000ltr	10,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby power supply	-NA-	-NA-	-NA-
18	Refuge Area.			
	<ul style="list-style-type: none"> Total Area 	-NA-	-NA-	-NA-

Location	-NA-	-NA-	-NA-
Fire Control Room			
• Detector System Panel	-NA-	-NA-	-NA-
• Flow Switch Panel	-NA-	-NA-	-NA-
• PA System Panel	-NA-	-NA-	-NA-
• Batter backup	-NA-	-NA-	-NA-
• Building Floor Plans	-NA-	-NA-	-NA-
20 Special Fire Protection Systems for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. **F.6/DFS/MS/School/WZ/2022/1014 dated 15.09.2022** is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

[Handwritten Signature]
23/9/22

Signature of the Inspecting Officer
Name : Ajay Kumar Sharma
Designation: ADO (Rohini)

DO (NW) N/A

Dy. CEO (WZ)

DCFO/481-N/A
Dated 30/09/25

[Handwritten Signature]
30/9/2025

[Handwritten Signature]
Principal Director

Dy. CEO to Secy.

[Handwritten Signature]
20/09/25

put up F.T.

[Handwritten Signature]
20/9/2025

[Handwritten Signature]
ADO (Rohini)

FT letter is put up for kind
perusal & signature please.

[Handwritten Signature]
DCFO

[Handwritten Signature]

[Handwritten Signature]
30/9/25

MS Cell