



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001



No. F.6/DFS/MS/EH/NDZ/2026/ 19

Dated: 14/01/2026

To,

Sh. Sourav Chawala,
M/S SEGRETO (A Unit of Innovio Gourmet LLP
Plot No. B-24, Defence Colony,
New Delhi-110049

Subject:- Application for issuance of Fire Safety Certificate in r/o M/S SEGRETO (A Unit of Innovio Gourmet LLP) Located at Plot No. B-24, Defence Colony, New Delhi-110049.

Sir,

This has reference to MCD application ID No. 2025121315677 dated 15/12/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 27/12/2025 in presence of Sh. Sourav Chawala. The premises is comprised of basement, stilt, ground plus three upper floors but restaurant is running first floor only. The following shortcomings were observed during the time of inspection.

1. Door size 1.40 meter and 1.42 meter are provided against the requirement of 1.50 meter each.
2. First-Aid hose reel and down-comer are provided but not functional.
3. MOEFA is provided but not functional.
4. Terrace pump capacity 900 lpm provided but not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(A. K. MALIK)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

The Commissioner, MCD, Civic Centre, New Delhi
MCD ID No. 2025121315677