

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

NO.F.6/DFS/MS/GH/2026/ 64

Dated: 06/03/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Center, Minto Road,
New Delhi-110002.

Sub:- Reply of application regarding FSC/NOC in r/o **Segreto A Unit of Innovid Gourmet LLP** located at **B-24, 3rd floor, Defence Colony, Delhi 110024.**

Sir,

This has a reference to online ID- **2026020501288 Dt. 05/02/2026** on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 14/02/2026 in the presence of Mr. Mohammad Tariq (Manager). During course of inspection, the shortcomings observed are as below: -

1. Fire Check door at one exit is not provided.
2. Door size of one exit is 1.4m against the requirement of 1.5m.
3. First-Aid Hose Reels found non-functional.
4. Internal Hydrants also found non- functional.
5. One electric main pump of 2280 LPM, 01 stand by pump of 2280 LPM & 01 jockey pump of 180 LPM capacity are not provided at per NBC Part IV, 2016.
6. Terrace pump is provided but found non-functional.
7. Auto starting of terrace pump found non-functional.
8. Underground water tank of 1,00,000ltrs capacity is not provided.

In view of the above, application for fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of owner/occupier of the establishment. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(A. K. Malik)
Dy. Chief Fire Officer

Copy to: -

1. Mr. Mohammad Tariq (Manager), M/s Segreto A Unit of Innovid Gourmet LLP located at B-24, 3rd floor, Defence Colony, Delhi 110024