

c/19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2025/SZ/ 499

Dated: 16/04/2025

FIRE SAFETY CERTIFICATE

Certified that the **Sevti Devi Memorial Vidya mandir** at Opp Dashrath Puri Metro Station, Mahavir Enclave, Dwarka, New Delhi- 110045, comprised of small basement (storage) ground plus one upper floor, owned/occupied by Sevti Devi Memorial Vidya mandir, was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/SZ/2022/School/313 dated 25.03.2022. The school building was re- inspected by the officer concerned of this department on 04.04.2025 in the presence of Ms. Tushita Vats (Principal) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. 262-362 dated 17.01.2005 issued by the Director of Education and that the building/premises (**ground and first floor only**) is fit for occupancy class "**Educational Building**" w.e.f. 16/04/2025 for a period of three years, subject to compliance of the conditions printed as under.

Issued on 16/04/2025 at New Delhi by.


(Atul Garg)
Director

Delhi Fire Service

901-7/4

Copy to: -

1. The Executive Engineer (Bldg.), MCD, Civic Centre, New Delhi: - for information regarding use of basement.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
3. The Principal, Sevti Devi Memorial Vidya mandir at Opp Dashrath Puri Metro Station, Mahavir Enclave, Dwarka, New Delhi- 110045.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws. Presently basement used for storage.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Sevti Devi Memorial Vidya Mandir, Near Dashrath Puri Metro Station, Mahavir Enclave (Dwarka), New Delhi- 110045.
2. Building comprised of : Small basement (store), ground plus one upper floors (school)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/SZ/2022/School/313 dated 25.03.2022
6. Fire Safety directives letter No : Circular No. 262-362 dated 17.01.2005
7. Date of inspection : 04.04.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Ms. Tushita Vats (Principal)
10. Year of Construction : 2009
11. Applicant's letter No. : F-1-2/SDMVM/F/2025 dated 21.03.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per FSC dt. 25.03.2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6.0 m 4.5 m N/A	Provided Provided N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 no.'s N/A	02 no.'s N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 m 1.50 m	1.66 & 1.18 m 1.06 & 0.54 m	MR, old case MR, old case
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
		1.5 m	Provided	MR
	e. Width of Corridor			
	f. Class room Door Size	1.0 m	.90 m	MR, old case
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	12.30 a/c per hour 12 a/c per hour	Exhaust fan provided Provided	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	08 No's ABC/CO ₂ type ISI marked	Provided Provided ISI marked	MR MR MR

N/13

Provision of Lifts.		(No Lift)		
<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.	N/A	N/A	N/A
	<ul style="list-style-type: none"> > Total Area > Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	ABC fire extinguisher provided near electric panel	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/SZ/2022/School/313 dated 25.03.2022, renewal in accordance with the Circular No. 262-362 dated 17.01.2005 issued by the Director of Education is recommended.

R.K. Yadav
8/04/2025

Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

DO (SW)

R.K.
9/4/25

C.R.S.
11/4/2025

Director *[Signature]*