

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.

No. F.6/DFS/MS/School/2025/SZ/ 308

Dated: 27/03/2025

FIRE SAFETY CERTIFICATE

Certified that the **Shanti Gyan Niketan Jr. School** at Goyla (Dwarka), Near Sector-19, New Delhi-110071, comprised of two blocks namely Junior Block and Middle Block. Junior Block is having Ground floor plus one upper floor and Middle Block is having ground floor plus two upper floors owned/occupied by the Shanti Gyan Niketan Jr. School was issued FSC by this department vide letter No. F.6/DFS/MS/School/2022/SZ/210 dated 25.02.2022. The school building was re-inspected by the officer concerned of this department on dated 19.03.2025 in the presence of Sh. Ashwani Kumar Khurana (Manager) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with circular issued by D.O.E circular dt. 01.03.11 and rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" w.e.f. 27/03/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 27/03/2025 at New Delhi by.


(Ajit Garg)
Director
Delhi Fire Service
07/03/25

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Shanti Gyan Niketan Jr. Public School at Goyla (Dwarka), Near Sector-19, New Delhi-110071.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Shanti Gyan Niketan Jr. School, Goyla (Dwarka), Near Sector-19, New Delhi-110071
2. Building comprised of : Two blocks Junior & Middle, Junior blk having ground plus one upper floor and Middle blk is having ground plus two upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2022/SZ/210 dated 25.02.2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 19.03.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav (JKP)
9. Name and designation of officers
From the building side : Sh. Ashwani Kumar Khurana (Manager)
10. Year of Construction : 1996-97 (Jr. Blk GF & FF) & 2015-16 (M. Blk GF, FF & SF)
11. Applicant's letter No. : Form 'J' dated 13.02.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dt. 25.02.2025	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible (06 m) 4.5 m N/A	06 m Directly accessible from road N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03 No.'s in Jr. blk & 02 no.'s in M blk	03 No.'s in Jr. blk & 02 no.'s in M blk	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	1.50 & .75 m in Jr. blk & 1.50 m each in M blk	1.67, 1.22 & 1.22 m in Jr. Blk & 1.53 & 1.60 m in M blk	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
		Required	One	MR
	e. Width of Corridor	1.50 m	4.0 m in Jr. blk & 1.50 m in M blk	MR
	f. Door Size	1.0 m	1.45 m and .91 m in Jr. Blk & 1.10 m in M blk	MR, students are less than 45 in each class room
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	04 no's/floor in each blk	Provided	MR
	• Types	ABC/CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR


N/15

16.	Provision of Lifts.	(No Lift)		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	Provided	N/A
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - As per undertaking submitted by the manager of the school (placed at C-25) that the strength of every class should be less than or equal to 40 students only.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2022/SZ/210 dated 25.02.2022, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.



 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

D.O. (South West)


25/2/25

CFO
21/3/2025

Director
25/02/2025



PTD