

L-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/School/2025/SZ/ 309

Dated: 27/03/2025

FIRE SAFETY CERTIFICATE

Certified that the **Shanti Gyan Niketan Sr. Sec. Public School, Goyla (Dwarka), Near Sector-19, New Delhi-110071**, comprised of ground floor plus three upper floors, owned/occupied by Shanti Gyan Niketan Sr. Sec. Public School was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2022/SZ/211 dated 25.02.2022. The School building was re-inspected by the officer concerned of this department on dated 19.03.2025 in the presence of Sh. Ashwani Kumar Khurana (Manager) and found that School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (**ground plus three upper floors**) is fit for occupancy class "**Educational**" w.e.f. 27/03/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 27/03/2025 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Shanti Gyan Niketan Sr. Sec. Public School at Goyla (Dwarka), Near Sector-19, New Delhi-110071.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/14

INSPECTION REPORT

1. Name & address of the building : Shanti Gyan Niketan Sr. Sec. Public School, Goyla (Dwarka), Near Sector-19, New Delhi-110071.
2. Building comprised of : Ground plus three upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
- Details of Previous NOC : F.6/DFS/MS/School/2022/SZ/211 dated 25.02.2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 19.03.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav (JKP)
9. Name and designation of officers
From the building side : Sh. Ashwani Kumar Khurana (Manager)
10. Year of Construction : 1994-95
11. Applicant's letter No. : Form "J" dated 13.02.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 m 4.5 m N/A	06 m Directly accessible from road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 No.'s	02 No.'s	M/R
	• Basement	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	1.50 & .75 m	1.37 to 1.48 & 1.20 m	M/R
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	Two	M/R
	e. Width of Corridor	1.50 m	Provided	M/R
	f. Door Size	1.0 m	1.40 m (Single door)	M/R
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	• Total numbers	04 no's/floor	Provided	M/R
	• Types	ABC/CO ₂ type	Provided	M/R
	• IS marking	ISI marked	Provided	M/R
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	M/R
	• Length of hose reel hose	30 m	Provided	M/R
	• Nozzle diameter	5 mm	Provided	M/R

7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	100 mm	N/A
	• Number of hydrants per floor	N/A	One	N/A
	• Hose Box	N/A	One	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM & 180 LPM	MR
	➤ Head of the pump	30 m	Provided	M/R
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/16

17.	Standby power supply	N/A	Provided	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection

Note: - As per undertaking submitted by the school manager (placed at C-19) that the strength of students at every class should be less than or equal 40 students only and there will be two doors in library.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide No. F.6/DFS/MS/School/2022/SZ/211 dated 25.02.2022, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

DO (SW)

R.K.
 21/3/25

CFO
21/3/2025

Director
 29/03/25

Princip

FT, letter is put up for sign please

DIRECTOR
 27/03/25

R.K.
 27/3/2025