

c/26



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 04

Dated: 02/01/2025

To,

The Principal
Shanti Vidya Mandir, D-1, Rajeev Nagar,
Bhalaswa Dairy Colony, Delhi-42.

Sub: - Regarding renewal of fire safety certificate in r/o Shanti Vidya Mandir School located at D-1, Rajeev Nagar, Bhalaswa Dairy Colony, Delhi-110042.

Sir,

Please refer to your letter received through email I.D dated 18.12.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 28.12.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground and ground & 02 upper floors only. At the time of inspection Smt. Soma Devi (Principal) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. Fire extinguisher provided but not functional.
2. Hose reel hose provided but badly damaged/leakage condition.
3. Terrace level firefighting pump capacity of 450lpm is provided but found badly damaged condition and also power supply, auto mode system not functional at the time of inspection.
4. Terrace level fire water tank capacity of 10,000ltrs is found removed at terrace level.
5. Exit signage and floor signage found removed at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Dy. Director, Education Department, Zone-IX, District North West-A, BL-Block, Shalimar Bagh.