



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001




No. F.6/DFS/MS/School/2025/SZ/ 1207

Dated: 29/09/2025

FIRE SAFETY CERTIFICATE

Certified that the building of Sharda Devi Memorial Public School located at RZF-368, Raj Nagar-II, Palam Colony, New Delhi-110045, comprised of Ground + One upper floors, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2022/SWZ/School/473 dated 29/04/2022. The premise was re-inspected by the officer concerned of this department on 19/09/2025 in the presence of Sh. Rakesh Kumar (Manager) and found that said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the school premise/building is fit for occupancy class "Educational Group B" with effect from 29/09/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/09/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. Manager, Sharda Devi Memorial Public School, RZF-368, Raj Nagar-II, Palam Colony, New Delhi-110045

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection.
3. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

14-15

INSPECTION REPORT

1.	Name & address of the building	Sharda Devi Memorial Public School located at RZF-368, Raj Nagar-II, Palam Colony, New Delhi-110045		
2.	Type of occupancy	Educational, Group-B (School)		
3.	Building comprised of	Ground plus one upper floor.		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F6/DFS/MS/2022/SWZ/School/473 Dt. 29/04/2022		
6.	Fire safety directives letter No.	DOE Circular 3298 to 3398 dated 01/03/2011		
7.	Date of Inspection	19/09/2025		
8.	Name of the Inspecting Officer	ADO (DWK)		
9.	Name and designation of Officer from the building side.	Sh. Rakesh Kumar (Manager)		
10.	Year of construction	Before 2006		
11.	Applicant's letter No.	No. Nil dated 20/08/2025 received through outdoor diary No. 5061 dated 20/08/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	OLD NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6.0 mtr 4.5 mtr N/A	Provided Provided N/A	MR MR N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	➤ Upper floors	2 Nos	Provided	MR
	➤ Basements	N/A	N/A	N/A
	b. Width of staircases			
	➤ Upper floors	1.5m / 0.75m	1.5m & 1.0m	MR (Old Case)
	➤ Basements	N/A	N/A	N/A
	c. Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.0 mtr	0.80m to 1.0m	MR (Old Case)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N/A N/A	N/A N/A	N/A N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers at each floor • Types • IS marking 	Required ABC/CO ₂ ISI marked	06 Nos ABC & CO ₂ Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Required Required Required	One 30 mtr 5 mm	MR MR MR

N-17

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A		N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	Required	ABC type fire extinguisher provided near elect. meter	MR


The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection. The shortcomings issued by this department vide letter No. F.6/DFS/MS/School/2025/SZ/520 dated 10/06/2025 found complied.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/2022/SWZ/School/473 dated 29/04/2022, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, DFA is put up for approval & signature please.




Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (DWK)

~~DO (SW)~~ 
 24/9/25

~~CFD~~ 
 24/9/2025

~~Principal Director~~

CFD to Issue

 25/08/25

~~CFD~~ 

ADO (DWK)

Sir, F.T letter is put up for your sig. pl


 20/08/25

~~CFD/HB~~ 
 29/9/2025

MS