

c/73

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

N F6/DFS/MS/GH/NDZ/ 196

Dated: 24.04.2025

To,

The Manager
M/S Sharma Hotel at 894, S.P.M. Marg,
Behind Novelty Cinema, Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o Sharma Hotel at 894, S.P.M. Marg, Behind Novelty Cinema, Delhi.

Sir,

This has reference to online id no. 2025032804831 dated 28.03.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 19/04/25 in the presence of Mr. Ram Avtar and following shortcomings were observed: -

1. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.
2. Hose reel found nonfunctional.
3. Pump found nonfunctional and not in auto provision also.

Hence, Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police(lic), Ist floor, Defence Colony Police Station, New Delhi.