

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**


No. F.6/DFS/MS/School/2026/SZ/ 07 **NEW DELHI-110 001.**

Dated: 09/01/2026

**FIRE SAFETY CERTIFICATE**

Certified that the Shri Lakshmi Maha Vidyalaya (of Lahore) Management Society at P. No. Nursery School, Faiz Road (Redevelopment of Ashok Nagar), Karol Bagh, New Delhi- 110005, running at upper ground plus two upper floors in a building comprised of basement, stilt, upper ground plus two upper floors. (basement is closed and not in use & stilt for parking), owned/occupied by Shri Lakshmi Maha Vidyalaya (of Lahore) Management Society. The school building was inspected by the officer concerned of this department on dated 12.12.2025 in the presence of Mr. Naresh, and found that the building/ premises is fit for occupancy class B "Educational Building" with effect from 09/01/2026 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 09/01/2026 at New Delhi.

  
 8/1/26  
 (A.K. Malik)  
 Dy. Chief Fire Officer  
 South Zone

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.
2. Sh. Deepak Mittal, Shri Lakshmi Maha Vidyalaya (of Lahore) Management Society at P. No. Nursery School, Faiz Road (Redevelopment of Ashok Nagar), Karol Bagh, New Delhi- 05.
3. The Executive Engineer (Bldg.), MCD, Civic Centre, New Delhi.

: - for information regarding use of basement.

**Conditions for validity of fire safety certificate: -**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Presently basement is closed and not use for any purpose.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/4

## INSPECTION REPORT

- |                                     |   |   |
|-------------------------------------|---|---|
| 1. Name & address of the building   | : | Sh. Lakshmi Maha Vidyalaya (of Lahore) at P. No. Nursery School, Faiz road, (Redevelopment of Ashok Nagar), Karol Bagh, New Delhi- 110005 |
| 2. Type of Occupancy                | : | Educational   |
| 3. Type of Case                     | : | Basement (Closed), stilt (parking), upper ground plus two upper floors  |
| 4. Details of Previous NOC          | : | New Case  |
| 5. Fire Safety directives letter No | : | N/A   |
| 6. Date of inspection               | : | F.6/DFS/MS/BP/2019/276 dated 31.07.2019   |
| 7. Name of Inspecting Officer       | : | 12.12.2025  |
| 8. Name and designation of officers | : | A.D.O. R.K.Yadav  |
| 9. Year of Construction             | : | Sh. Naresh  |
| 10. Applicant's letter No.          | : | Before 2019   |
|                                     | : | Online email Id <kasushikmonu50@gmail.com> dated 04.12.2025   |

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>	UBBL/NBC		
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible 06 m 4.5 m N/A	06 m Directly accessible from road N/A	MR MR N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 No's N/A	02 No's N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.50 m each N/A	1.50 m each N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	02 No's	Provided	MR
	e. Width of Corridor	1.50 m	Provided	MR
	f. Door Size	1.20 m	Provided	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	N/A Required	N/A Natural ventilation	N/A MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Types</li> <li>• IS marking</li> </ul>	20 no.'s ABC/CO <sub>2</sub> type ISI marked	Provided Provided ISI marked	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	01 no's 30 m 5 mm	Provided Provided Provided	MR MR MR

N/S

7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	900 LPM	MR
	➤ Head of the pump	40 m	40 m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 ltrs	25,000 ltrs	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts. No Lift</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/6

	Standby power supply	Required	Provided	MR
	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
<b>19.</b>	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - The Fire safety guidelines issued vide letter No. F.6/DFS/MS/BP/2019/276 dated 31.07.2019 proposed for building comprised of basement, stilt, ground plus two upper floors, As per undertaking submitted by the school management (placed at C-19 & 20) that the school management closed the basement by brick wall, stilt use for parking and school running at ground plus two upper floors. Fire protection system for educational building is provided as per NBC-2016. *If agreed, we may consider the building for FSC with requirements as per NBC Part-III.* Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures under Rule 35 of the Delhi Fire Service Rules 2010, it's recommended to grant Fire Safety Certificate.

*R.K. Yadav*  
 Signature of the Inspecting Officer  
 Name- R.K. Yadav  
 Designation- ADO (SRD)

DO (South West)

*R.K.*  
 5/1/26

*Dy. CFO (SRD)*

*A.K. Malik*  
 6/1/26  
 A.K. MALIK

*Principal Director*

*Dy. CFO to Secy.*  
 06/01/26

*Dy. CFO (SRD)*

*A.K. Malik*