



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2026/NZ/ 883

Dated: 17/09/2026

To,

The Principal,
Shri Veda World Early Years School,
B-371, Ground Floor, Lok Vihar,
Pitampura, Dlehi-110034.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Shri Veda World Early Years School located at B-371, Ground Floor, Lok Vihar, Pitampura, Dlehi-110034.

Sir,

This has reference to your letter received through outdoor diary no. 5433 dated 21.08.2026 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 02.09.2026 in presence of Sh. Deepak to see the compliance of requisite fire safety measures. During the course of inspection, it is observed that school is running at Ground floor only in a building is comprised of Ground plus three upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:

1. Smoke ventilation system found not provided.
2. Building plan in a scale of 1:100 duly signed by registered architect and owner is not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

O/C

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, Delhi.