



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/GH/NDZ/2024/751

Dated: 31/12/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Ref: elt.mcdonline application no. 2024101215589

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Shyam Guest House located at 4234, Tel Mandi, Pahar Ganj, New Delhi.

Sir,

With reference to the elt.mcdonline application no. 2024101215589 on the subject cited above, it is informed that the said guest house was inspected by the officer concerned of this department on. 23.12.2024 in the presence of Mr. Ameer (Manager) and following shortcoming were observed at the time of inspection.

1. Hose reel found non functional.
2. CO detector found non functional.
3. Manual Operated Electrical Fire Alarm (MOEFA) system found non functional.
4. Fire pump found non functional.
5. Guest house was also found running at 4th & 5th floor though owner has submitted an affidavit dated 05.12.2019 not to use any floor above 3rd floor. Closure/sealing of the same shall be ensured by the local authority/licensing authority.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

26/12/24 27/12 50

Copy to :-

1. The Executive Engineer (Bldg.), MCD, 9th Floor, Dr. SPM Civic Centre, Minto Road, New Delhi-110002. To verify the height of the building under intimation to this department.