



2148



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No. F.6/DFS/MS/Banqt./NDZ/2026/270

Dated: 30/03/2026

To,

Sh. Nitin Gupta,  
M/s Silver Line Banquet Hall,  
Plot No D-58, Dilshad Colony,  
Delhi 110095.

**Subject: - Regarding renewal of Fire Safety Certificate in r/o M/s Silver Line Banquet Hall located at Plot No D-58, Dilshad Colony, Delhi 110095.**

Sir,

This has a reference to MCD online application ID No. 2026022502027 dated 25/02/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 18/03/2026 in presence of Sh. Sanjay Gupta and observed that building comprised of basement, stilt, ground, plus two upper floors. Following shortcomings were observed during time of inspection:

1. The two meter door at the rear staircase has been found temporary closed off by installing a stage.
2. Fire check doors found removed as marked in the plan.
3. Staircases serving to basement are not segregated.
4. Smoke management system found removed in the basement and upper floors.
5. First aid hose reels provided but not functional.
6. Detector system provided but not functional.
7. Fire Fighting system is not on auto mode.
8. Overhead tank capacity 15,000 liters provided against the requirement of 25,000 liters.
9. Exit Signages/Lift Signages not provided.
10. Pressurization systems of the lift shaft, staircases and lift lobbies not provided.

Keeping in view of above shortcomings, the application for issuance of Fire Safety Certificate can not be considered at this stage. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Dr. S. K TOMAR)  
DY. CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

o/c R

Copy to:-

1. The Commissioner, MCD, Dr. S.P. M. Civic Centre, Minto Road, New Delhi-110002  
MCD ID No. 2026022502027