



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001


No: F.6/DFS/MS/School/SZ/2026/ 153

Dated: 18/09/2026

FIRE SAFETY CERTIFICATE

Certified that the Singhal Public School located at L-1st, 2073, Near Asthal Mandir, Sangam Vihar, New Delhi-80, comprised of total two blocks (Old Block- ground plus two upper floors and new Block- ground and three upper floors, both blocks are interconnection at all floor level), was earlier issued FSC vide letter No. F6/DFS/MS/School/2019/SZ/1506 dated 23/07/2019. The premises was re inspected by the officer concerned by this department on 24/08/2026 in the presence of Sh. Mahavir Singh and observed that have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the fit for occupancy class **"Educational Building" Group-B** with effect from 18/09/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on 18/09/2026 at New Delhi.


(A.K. Malik)
Chief Fire Officer

Copy to: -

1. The manager/Principal, Singhal Public School located at L-1st, 2073, Near Asthal Mandir, Sangam Vihar, New Delhi-80.(Online ID No. - 52026041402222).
2. The Director, Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to nonfunctional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction, electrical installation, lift, setback area etc., shall be verified by the concerned sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. All the means of escape such as exit, corridor, passageway, etc., shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT


1. Name & address of the building		Singhal Public School located at L-1 st , 2073, Near Asthal Mandir, Sangam Vihar, New Delhi-80.		
2. Type of Occupancy		“Group-B” Educational Building, comprised of total two blocks (Old Block- ground plus two upper floors and new Block- ground and three upper floors, both blocks are interconnection at all floor level)		
3. Type of Case		Renewal		
4. Details of previous NOC		F6/DFS/MS/School/2019/SZ/1506 dated 23/07/2019		
5. Fire Safety directives letter No		DFS Act 2007& Rule, 2010		
6. Date of inspection		24/08/2026		
7. Name of the Inspecting Officers		Sh. Sarabjeet Singh ADO (Malviya Nagar)		
8. Name and designation of officers from the building side		Sh. Mahavir singh		
9. Year of Construction		2000 & 2010		
10. Applicant’s letter No.		Online ID No.-52026041402222		
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessibility 06m	Accessibility 06m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	G+02=01 nos. G+3=01 nos.	G+02=01 nos., G+3=01 nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m /0.75m	G+2=1.35m, G+3=1.60m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01 nos.	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01 m class room	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	12 Nos. CO ₂ , ABC type ISI marked	Provided	MR
	• Types		ABC & CO ₂	MR
	• IS marking		Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01 Nos.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	05mm	Provided	MR


7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of main panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift Lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA


17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	• Total Area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA


The fire protection systems provided in the building were checked randomly and found functional at the time of inspection. Earlier all the shortcomings issued by this department vide letter No. F6/DFS/MS/School/SZ/2022/665 dated 01/11/2022 have been rectified.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/2019/SZ/1506 dated 23/07/2019, renewal under the rule 37 of the Delhi Fire Service rules 2010 is recommended. Accordingly, DFA is put up for approval and signatures please.



 Name: Sarabjeet Singh
 Designation: ADO/Malviya Nagar

DO(SD) 
 11/8/20
Ravinder Singh


 3/9/24
A.K. MALIK

Mr. Dh. 
 Received on 14/9/24.
 C/o (SST)


 14/9/24
A.K. MALIK

DO(SD) 
 14/9/24
Ravinder Singh