



No.F6/DFS/MS/2026/WZ/EH/ 136


Dated 12 /02 /2026

FIRE SAFETY CERTIFICATE

Certified that the M/s The Sial Kitchen (A Unit of RSK Hospitality) located at Plot No. DDA Market, R-1, First Floor, CSC-5, Sector-14, Rohini, Delhi-110085 in a Building comprised of Ground + 02 Upper floors, Owned/Occupied by M/s The Sial Kitchen (A Unit of RSK Hospitality) was granted FSC by this department vide letter No. F6/DFS/MS/2023/WZ/EH/30 Dated 24/01/2023. The premises was inspected by the officer concerned of this department on 03/02/2026 in the presence of Mr. Ghanshyam (Manager) and found that the said premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly Building Group-D (Restaurant) for first floor only**" with effect from 12/02/2026 for period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 12/02/2026 at New Delhi by


12/02/26
S.K. Dua

Dy. Chief Fire Officer
Delhi Fire Service


Copy to: -

1. The Commissioner, Municipal Corporation of Delhi, to ensure the occupancy as detailed above deviation and if any. Online Portal ID- 2026011300432 dated 14/01/2026.
2. M/s The Sial Kitchen (A Unit of RSK Hospitality) located at Plot No. DDA Market, R-1, First Floor, CSC-5, Sector-14, Rohini, Delhi-110085.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in Form "**K**" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the MCD portal along with a copy of this Certificate, **six months** prior to its expiry".
8. This Fire Safety Certificate is valid only for restaurant at first floor. In case of any violation, this FSC will be treated as null & void.

INSPECTION REPORT

1. Name & address of the building : M/s The Sial Kitchen (A Unit of RSK Hospitality) DDA Market, R-1, First floor, CSC-5, Sector-14, Rohini, Delhi-110085.
2. Type of Occupancy : Group-D "Assembly (Restaurant)"
3. Composition of building : Ground & 02 upper floor **But Restaurant is running in 1st floor only**
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2023/WZ/EH/30 Dated 24/01/2023
6. Fire Safety directives letter No : 2005 Circular
7. Date of inspection : 03/02/2026
8. Name of Inspecting Officer : ADO (Rohini)
9. Name and designation of officers
From the building side : Sh. Ghanshyam (Manager)
10. Year of Construction : 2000
11. Applicant's letter No. : Online MCD Portal ID No. 2026011300432 dated 14/01/2026

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	2005 Circular Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	6m -NA- -NA-	Provided -NA- -NA-	MR -NA- -NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 -NA-	02 -NA-	MR -NA-
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	Required -NA-	1.5m -NA-	MR -NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required -NA-	Provided -NA-	MR -NA-
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	Required	2.0m & 1.1m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	-NA- 12 ACPH	-NA- Natural ventilated	-NA- MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04nos. ABC/CO ₂ ISI	06nos. AB-4C/CO-02 Provided	MR MR MR

6. First-Aid Hose Reels				
<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	Provided	MR	
	30m	Provided	MR	
	5mm	Provided	MR	
7. Automatic fire detection and alarming system				
<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Co2	Provided	MR	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
8. MOEFA	Required	Provided	MR	
9. Public Address System	-NA-	-NA-	-NA-	
10. Automatic Sprinkler System				
<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-	
	-NA-	Provided	-NA-	
	-NA-	-NA-	-NA-	
11. Internal Hydrants				
<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
12. Yard Hydrants				
<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
13. Pumping Arrangements				
<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	450 LPM	450 LPM	MR	
	40m (each)	40m	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	14. Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	-NA-	-NA-	-NA-
-NA-		-NA-	-NA-	
-NA-		-NA-	-NA-	
-NA-		-NA-	-NA-	
√5000 Ltr.		Provided	MR	

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F6/DFS/MS/2023/WZ/EH/30 Dated 24/01/2023, **renewal** under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Received on 09/02/2026

Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO (R)

~~DO (NW)~~ For Approval PL.

~~Dy CFA (WZ)~~

~~Pr. Director~~

1
 Approval
 09/02/2026

~~King~~
 10/02/26

~~Dy. CFA to Insp.~~

~~Dy. CFA (WZ)~~

~~Q~~
 11/02/26

F.T. please.

~~ADO (Lohini)~~

~~King~~

cont. DT

12/02/26