

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

254
7
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/EH/2025/ 48

Dated:- 11/02/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Somewhere Restaurant and Bar, Located at H-10, Ground Floor, Outer Circle Connaught Place, New Delhi-110001, The building is comprised of Ground Floor + Mezz. Floor + 02 Upper Floors but Restaurant is running at Ground Floor and Store & Kitchen at Mezz. Floor only, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/EH/NDZ/2022/53 dated 28/02/2022. The said premise was re-inspected by the officer concerned of this department on 31/01/2025 in the presence of Sh. Shivam Soni (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" Group D (Restaurant at ground and kitchen & store at mezz. floor only) with effect from 11/02/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on11/02/2025 at New Delhi by.

(Atul Garg)
Director

Tel. No. 011-23414000

Copy to: -

1. The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi:- in r/o computer id no. 2025011600594 dated 16/01/2025
2. The Authorized Signatory, M/s. Somewhere Restaurant and Bar, H-10, Ground Floor, Outer Circle Connaught Place, New Delhi-110001.

Following fire safety certificate must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. Any flammable material for interior decoration shall be strictly prohibited.

INSPECTION REPORT

1. Name & address of the building : M/s. Somewhere Restaurant and Bar, located at H-10, GF, Street, Laxmi Building Connaught Place, New Delhi.
2. Type of Occupancy : Assembly,
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/NDZ/2022/53 dated 28/02/2022
5. Fire Safety directives letter No : N/A
6. Date of inspection : 31/01/2025
7. Name of the Inspecting Officers : Aman Kumar Lathar, ADO (JW)
8. Name and designation of officers from the building side : Sh. Shivam Soni (Manager)
9. Year of Construction : 1947 (Heritage Building)
10. Applicant's Online ID- : 2025011600594 dated 16/01/2025

GF. – Restaurant
Mezz. – Kitchen & Store
1st & 2nd floor – LIC
Officer's guest house
with separate Entry/Exit)

The building is comprised of ground floor, mezz. floor plus two upper floors but restaurant is running at ground floor & kitchen and store at mezzanine floor only.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per earlier FSC dated 28/02/2022	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m	09	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02 nos.	02 nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 m & 0.80 m	1.5 m & 1.10 m	MR (Old heritage)
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.5 m x 2	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A

4	Smoke Management System.			N/A
	• Basements	NA	N/A	N/A
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			MR
	• Total numbers	04 Nos.	Provided	MR
	• Types	ABC, CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			MR
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			N/A
	• Type of detectors	N/A	Provided	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			N/A
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			MR
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			MR
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A
	➤ Draw-off connection	N/A	N/A
	➤ Fire service inlet	N/A	N/A
	➤ Access to tank	N/A	N/A
	• Overhead Tank capacity	20,000 ltrs.	Provided
		Required	Provided
15	Exit Signage.		MR
16	Provision of Lifts.		MR
	• Pressurization of Lift Shaft	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A
	• Communication In lift Car	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A
	• Lift Signage	N/A	N/A
17	Standby power supply	Required	Provided
18	Refuge Area.		N/A
	➤ Total Area	N/A	N/A
	➤ Location	N/A	N/A
19	Fire Control Room		N/A
	• Detector System Panel	N/A	N/A
	• Flow Switch Panel	N/A	N/A
	• PA System Panel	N/A	N/A
	• Batter backup	N/A	N/A
	• Building Floor Plans	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the ~~deemed~~ compliance of minimum standards of fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/EH/NDZ/2022/53 dated 28/02/2022 is recommended under Rule 37 of the Delhi Fire Service Rules, 2010 under DFS Act 2007.

Accordingly DFA is put up for approval please.

[Signature]
03/02/25
Aman Kumar Lathar
ADO (JWP)

[Signature]
4/2/25

[Signature]
C.F.O. (NDZ)

[Signature]
06/02/25

[Signature]
C.F.O.
14/6/2025
Director

[Signature]
P.F.O.