



065



No. F6/DFS/MS/EH/NDZ/2026/211

Dated: 12/03/2026

FIRE SAFETY CERTIFICATE

Certified that the Somras Bar & Restaurant (Bhavya Infoway Pvt. Ltd.) running at Shop no. 10A, Ground floor of the building comprised of Basement + Ground + 02 upper floors located at Plot no. 01 A, Star City Mall, Mayur Vihar, District Centre, Delhi-91 & was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/NDZ/2023/215 dated 04/05/2023. The Restaurant was re-inspected by officer concerned of this department on 19.02.2026 in the presence of Mr. Vimal (Manager) and found that the Restaurant has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the said Restaurant at Ground floor only is fit for occupancy of Group D "Assembly Building" (Restaurant) with effect from... 12/03/2026... and valid upto 31.03.2029 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on ... 12/03/2026... at New Delhi by



(Dr. S.K. Tomar)

Dy. Chief Fire Officer (NDZ)
Delhi Fire Service

o/c 
10/3/26

Reference: etl.mcdonline application no. 2026021401617.

Conditions for the validity of Fire Safety Certificate

1. This Fire Safety Certificate is valid for Restaurant at Ground floor only.
2. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
3. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
4. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
5. The trained fire fighting staff should be available round the clock.
6. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
10. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT

1.	Name and address of the building:	M/s Somras Bar & Restaurant (Bhavya Infoway Pvt. Ltd.) located at Shop no. 10A, Ground floor, Plot no. 01 A, Star City Mall, Mayur Vihar, District Centre, Delhi-91.
2.	Type of occupancy	Group D, "Assembly" (Restaurant)
3.	Building comprised of	Basement + Ground + 02 upper floors. (Restaurant operational at Ground floor of the building)
4.	Type of case:	Renewal
5.	Details of previous FSC	F6/DFS/MS/EH/NDZ/2023/215 dated 04/05/2023
6.	Fire safety directives no.	F6/DFS/MS/BP/2004/1969 dated 30/08/2004
7.	Date of inspection:	19/02/2026
8.	Name of the inspecting officer:	Rajesh Kumar Shukla, ADO (L.N)
9.	Name and designation of the officer from the building side:	Mr. Vimal (Manager)
10.	Year of construction:	2004
11.	Reference letter no.:	etl.mcdonline application no. 2026021401617

S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements As per Rules 35 (6)	Provide at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	12.0 m	13.0 m	MR
	B Gate width	4.50 m	6.0 m	MR
	C Width of internal roads	6.0 m	6.0 m	MR
2	Number, Width, Type & Arrangement of Exits:			
	A No. of Staircase:	Restaurant at Ground floor only		
	a) Upper floor	NA	NA	NA
	b) Basements	NA	NA	NA
	B Width of the Staircase:	Restaurant at Ground floor only		
	a) Upper floors	NA	NA	NA
	b) Basement	NA	NA	NA
	C Protection of Exits			
	a) fire check door	Required in Kitchen	Provided	MR
	b) pressurization	NA	NA	NA
	D No. of continuous staircase to terrace	NA	NA	NA
	E Width of the corridor	NA	NA	NA
	F Door Size	2.0 m & 1.50 m	2.0 m x 2 nos.	MR
3	Compartmentation:			
	A Fire check doors	NA	NA	NA
	B Sealing of horizontal & vertical opening	Required	Sealed	MR
	C Fire rating of shaft doors	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke Management System:			
	A Basements	NA	NA	NA
	B Restaurant area	Required	Provided	MR
5	Fire Extinguishers:			
	A Total numbers	02 nos.	04 nos.	MR
	B Types	ABC & CO ₂	ABC & CO ₂	MR
	C ISI marking	ISI marked	ISI marked	MR

6	First Aid Hose Reel:			
A	Total no. at each floor			
B	Length of hose reel	01 no.	01 no.	MR
C	Nozzle diameter	30 m	30 m	MR
7	Automatic Fire Detection and Alarm System (ADAS): (Entire Mall)			
A	Type of detectors	Smoke/Heat	Provided	MR
B	Location of main panel	Control room in basement	Provided	MR
C	Location of repeater panel	Security room	Provided	MR
D	Alternate power source	Battery & DG Set	Provided	MR
E	Hooter's location	Required	Provided	MR
8	MOEFA:			
9	Public Address System:			
10	Automatic Sprinkler System:			
A	Basement	NA	NA	NA
B	Ground floor	Required	Provided	MR
C	Sprinklers above false ceiling	Required	Provided	MR
11	Internal Hydrants: (Entire Mall)			
A	Size of down comer	100 mm	100 mm	MR
B	No. of hydrants per floor	01 no.	Provided	MR
C	Hose box	02 nos.	Provided	MR
12	Yard Hydrants:			
A	Total no. of hydrants	NA	01 no.	NA
B	Hose box	NA	01 no.	NA
13	Pumping Arrangements: (Entire Mall)			
A	Ground Level			
a)	Discharge & head of main pump	4500 LPM & 50 m	4500 LPM & 50 m	MR
b)	Number of main pump	02 nos.	02 nos.	MR
c)	Discharge & head of jockey pump	450 LPM & 50 m	450 LPM & 50 m	MR
d)	Discharge & head of standby pump	4500 LPM & 50 m	4500 LPM & 50 m	MR
e)	Auto starting/ manual stopping	Required	Provided	MR
B	Terrace Level			
a)	Discharge of terrace pump	NA	NA	NA
b)	Head of terrace pump	NA	NA	NA
c)	Alternate power supply	NA	NA	NA
d)	Auto starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting: (Entire Mall)			
A	Underground tank capacity	2,00,000 ltrs	2,00,000 ltrs	MR
B	Draw off connection	Required	Provided	MR
C	Fire service inlet	Required	Provided	MR
E	Access to tank	Required	Provided	MR
D	Overhead tank capacity	25,000 ltrs	Provided	MR
15	Exit Signage:			
16	Provision of lift:			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Fireman switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	Standby Power Supply:			
18	Refuge Area:			
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room:			
A	Fire detection system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P a system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA

M/s Somras Bar & Restaurant (Bhavya Infoway Pvt. Ltd.) located at Shop no. 10A, Ground floor, Plot no. 01 A, Star City Mall, Mayur Vihar, District Centre, Delhi-91.

20	Special Fire Protection for special risk if any			
A	Special Fire Protection system for Protection of Special Risk, if any:	NA	NA	NA

LEGENDS:-Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Not Provided (NP) Provide But Not Functional (PNF).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2023/215 dated 04/05/2023 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

[Signature]
 25/12/26
 Signature of the Inspecting Officer
 Name Rajesh Kumar Shukla
 Designation ADO (L.N)

What about FSC of mall.
 D.O (East)
[Signature]
 26/12/26

ADDO (L.N) FSC of the Mall was renewed on 27.11.2024 and the copy of the same and its inspection report is placed on file. Submitted pls
[Signature]
 02/3/2026.

DO (ED)
[Signature]
 26/12/26

Dy. CFO (NDZ)
[Signature]
 2/3/26

Principal Director
[Signature]
 My. CFO to Gen.
[Signature]
 06/02/26
 My. CFO (NDZ)
[Signature]
 2/3/26

ADDO (L.N) FSC is set up as approved
Dy. COO (NDZ)
[Signature]
 10/3/26
[Signature]
 11/3/26

ms
Uploaded
 13/3/26